Solvent Recovery and Recycle

John Gawalt Jaired Re

Department of Chemical Engineering Virginia Polytechnic Institute and State University Submitted: November 20, 2015 Revised: December 13, 2015

Acknowledgements

We are extremely grateful for the opportunity to revise our design report. The completion of our project would not have been possible without the continued support and guidance our professor, Dr. Bortner, and his teaching assistants. We would also like to thank Dr. Liu for his exceptional training in ASPEN Plus, and for providing us with relevant engineering heuristics necessary for a complete design.

<u>Contents</u>

| Acknowledgements | 2 |
|---|------|
| Executive Summary | 6 |
| 1. Introduction | 8 |
| 2. Process Description | 9 |
| i. P&ID | 9 |
| ii. Critical Streams | .10 |
| ii. Function of Major Equipment | .10 |
| a. Acetonitrile Column | . 10 |
| b. Toluene Column | .11 |
| c. Flash Drum | .11 |
| 3. Separation Tasks: Sizing and Costs | .12 |
| i. ACN Column | .12 |
| a. Binary Analysis and Operating Pressure | . 12 |
| b. Column Sizing and Pricing | .13 |
| c. Condenser and Reboiler Sizing | .14 |
| ii. Toluene Tower | .15 |
| a. Binary Analysis and Operating Pressure | . 15 |
| b. Column Sizing and Pricing | .16 |
| c. Condenser and Reboiler | . 17 |
| iii. Flash Drum | .18 |
| 4. Auxiliary Tasks: Sizing and Costing | .20 |
| i. Vacuum Pump | .20 |
| ii. Positive Displacement Pumps | .21 |
| iii. Reflux Drums | .21 |
| iii. Mixer | .22 |
| iv. Heat Exchanger Network | .22 |
| v. Storage Tanks | .24 |
| 5. Process Economics | .26 |
| i. Delivered Equipment Cos | .26 |
| III. Labor | .28 |
| IV. Manufacturing Cost | .28 |
| V. Rate of Return | .29 |

| 6. Safety and quality control | 32 |
|--|----|
| i. Spill Containment | 32 |
| ii.Fire Prevention | 32 |
| iii. Maximum Allowable operating Conditions | 33 |
| iv. HAZOP | 34 |
| v. Personal Protective Equipment | 34 |
| Acetonitrile | 35 |
| 7. Conclusion | 36 |
| Appendix A: Stream Tables | 38 |
| i. Table A-1 – Stream Table Part 1 | 38 |
| ii. Table A-2 – Stream Table Part 2 | 39 |
| iii. Table A-3 – Stream Table Part 3 | 40 |
| iv. Table A-4 – Stream Table Part 4 | 41 |
| Appendix B: Main Process Flowsheet | 42 |
| Appendix C: Equipment Summary | 43 |
| I. Distillation Column Summary | 43 |
| II. Reflux Drum Summary | 44 |
| III. Pump Summary | 44 |
| VI. Heat Exchanger Summary Part 1: E1 - E3,B | 46 |
| VII: Heat Exchanger Summary: E4,A-D | 46 |
| VIII: Mixer Summary | 47 |
| IX: Condenser and Reboiler Summary | 47 |
| X: Summary of Delivered Equipment Costs | 49 |
| Appendix D: FMEA Summary | 50 |
| i. FMEA Definitions | 50 |
| The subsequent pages outline the results of our Failure Mode and Effects Analysis. The tables below define the rank ordered severity, occurrence, and detection parameters | 50 |
| ii. FMEA Tables | 52 |
| Appendix E: HAZOP Summary | 60 |
| i. Determination of risk hierarchy | 60 |
| ii. Key Tables | 62 |
| Appendix F: Utility Summary | 0 |
| i. Electric Usage: | 0 |

| ii. Cooling Water Usage0 |
|---|
| iii. MEK Usage 1 |
| iv. Steam Usage 1 |
| Appendix G: Inherently Safer Design Checklist |
| Appendix H: Sample Calculations |
| i. Economics |
| a. Delivered Equipment Cost7 |
| b. Fixed Capital Investment7 |
| c. Total Product Cost7 |
| d. Working Capital Investment (WCI)7 |
| e. Total Capital Investment (TCI)7 |
| f. Labor Costs |
| g. Annual Operating Cost (Total)8 |
| h. SOYD Depreciation Value8 |
| i. After Tax Cash Flow8 |
| j. ROR9 |
| ii. Equipment Sample Calculations9 |
| a. Liquid Ring Vacuum Pump9 |
| b. Mixer:9 |
| c. Column Height9 |
| d. Flash Drum9 |
| Appendix I: References |

Executive Summary

The object of this report is to propose a potential solvent recovery system for an existing siloxane polymerization unit. The polymerization unit has three waste streams, each of which is sequentially separated into the desired components: Acetonitrile, Toluene, and P-Xylene. Solvent grade Acetonitrile and Toluene are both expensive components and it would be in our best financial interest to maximize the amount of recycled solvent.

Our design incorporates two packed distillation towers along with a single stage flash drum to achieve mass purities of 99.83% Acetonitrile and 99.92% Toluene.



Figure I-1: Main process Flow Sheet

Figure I-1 displays all equipment used in our process with the exception of the backup pumps. All modeling calculations and sensitivity analyses are handled by ASPEN+. Our process description section goes into detail about each major unit and its associated auxiliary tasks such as pressure and temperature changes.

Our economic analysis for this process is conducted using a 20 year Sum of Years Digits depreciation scheme assuming a tax rate of 40%. For a total capital investment of \$2.5 million our process earns an average of \$3.7 million annually after taxes. This corresponds to a 144% rate of return on our investment. We also examine the effect of product sales price on our rate of return to predict the long term viability of our design.



Figure I-1: This plot depicts the response of the rate of return when the product prices are subjected to change.

Figure I-1 Shows the behavior of our rate of return as a function of the product sales prices. From this plot it is clear that as long as the price for each component remains above \$1/kg, our process will continuously add value to the company.

Our process is also designed with safety as the highest priority. HAZOP, FMEA, and Inherently safer design analyses found later in this report verify that our process is designed to minimize loss in terms of employee health and equipment safety.

We thank you for taking the time to consider our design solution. Please do not hesitate to contact us with any additional questions or concerns you may have.

1. Introduction

The formation of siloxane based polymers takes place in solution with strong solvents such as acetonitrile and toluene. When the polymerization is complete, the solvents must be separated once more before they can be reintroduced to the system. This is the basic idea behind our design: to minimize financial losses due to wasted solvent.

Acetonitrile is very prevalent in the chemical industry and is commonly used as a solvent for liquidliquid or liquid-solid extraction. The major benefit of acetonitrile as a solvent is that it can dissolve both organic and inorganic materials. Similarly, toluene is commonly used in industry as an organic solvent, or gasoline additive. Our design is aimed at returning solvents to the polymerization unit to save on raw material cost for each of these solvents.

2. Process Description

i. P&ID



Figure 2-1: Process and Instrumentation Diagram for Solvent Recovery from a Siloxane Process.

P&IDs provide a basis in the developmental stage of system control schemes. This opens avenues to more in depth safety and operational investigations including FMEA and HAZOP. We converged on a system of sensors and controllers that will hold safe, steady state operation as long as possible. Streams around distillation columns should be equipped with temperature, flowrate, and pressure sensors. Streams entering and exiting heat exchangers should have temperature and flow sensors to ensure there is no cross flow, and sufficient heat is exchanged. Streams that enter or exit a pump must at least have a pressure sensor. Streams that exit into an open container that may contain chemicals above their flash point should have at least a temperature sensor and a control valve near the exit with an innate fail close setting. The recycle stream entering the heat exchanger must have a valve with an innate fail close setting. The stream exiting the mixer should have a temperature, pressure, and flow sensor to ensure the correct feed

specifications are met. All additional sensors are added to facilitate quick, efficient troubleshooting when an issue arises.

ii. Critical Streams

Our process is designed with the intent of returning pure acetonitrile and toluene to the siloxane plant for reuse. The polymerization process produces three effluent flows named feeds A, B, and C. **Table 2-1** below shows the compositions and flowrates for each of these feed streams.

| Stream | Flow Rate $\left[\frac{kg}{kg}\right]$ | Composition (wt%) | | |
|--------|--|-------------------|--------------|----------|
| | [hr] | Toluene | Acetonitrile | Siloxane |
| Feed A | 270 | 98.5 | 0 | 1.5 |
| Feed B | 60 | 96.5 | 2.0 | 1.5 |
| Feed C | 200 | 19.5 | 78.5 | 2.0 |

| Table 2-1: Feed | Stream | Compositions |
|-----------------|--------|--------------|
|-----------------|--------|--------------|

The main goal of this process is to return solvents of high enough purity to be reused in the initial polymerization plant. **Table 2-2** outlines the critical stream data for each effluent stream from our process.

| Stream Name | Flow Rate | Temp | Composition [wt. %] | | | |
|----------------|------------------------------|--------------|---------------------|---------|----------|----------|
| | $\left[\frac{kg}{hr}\right]$ | [°] | Acetonitrile | Toluene | P-Xylene | Siloxane |
| TOL Product | 362.8 | 4 | 0.073 | 99.92 | 0.003 | trace |
| ACN Product | 158.2 | 5 | 99.83 | 0.124 | 0.045 | trace |
| Waste | 36.6 | 27 | trace | 0.4 | 75.2 | 24.4 |
| Xylene Recycle | 85.0 | 27 | trace | 0.8 | 85.2 | 14 |

Table 2-2: Critical Product Stream Data

Table 2-2 is a compilation of the results from our ASPEN Plus simulations, showing the outlet temperature of each stream before it enters storage as well as the composition of each stream. More extensive stream tables are located in **Appendix A.** The following subsection consists of an overview of each major separation unit used in our process.

ii. Function of Major Equipment

a. Acetonitrile Column

The first major unit in our process is a 25 stage packed vacuum distillation column measuring 0.76 m in diameter. A vacuum pump is attached to the total condenser in this tower to ensure the separation is run at 0.1 bar. This unit is charged with feeds B, C, and a P-Xylene stream and it tasked with separating acetonitrile from the remaining mixture. P-Xylene is used to keep siloxane in solution and facilitate the separation of acetonitrile. The distillate stream from this tower is the final acetonitrile product at 99.83 % purity. This stream is then cooled below to 5 \mathcal{C} and stored. The bottoms of this column is fed to the second distillation tower. Specific sizing and costing information is covered in the discussion as well as in the equipment summary.

b. Toluene Column

Toluene is separated at atmospheric pressure in a 24 stage packed column with a diameter of 0.6m. This column is charged with the bottoms flow out of column one as well as feed A on stages 15 and 8 respectively. This column produces a distillate stream composed of 99.92% toluene. Similar to the column before, the toluene product is cooled below it's to a temperature of 27 $^{\circ}$ before being sent to storage. The bottom stream is comprised primarily of p-xylene and siloxane. This stream is fed to a flash drum to return xylene to the process.

c. Flash Drum

Our flash drum operates near the vaporization point of P-Xylene at a temperature of ##### $^{\circ}$ and a vapor fraction of 0.72 entering the drum. Siloxane is an undesired waste product and must be make up no more than 25% of any stream to avoid solid formation within the system. We desire to recover as much of our separating agent as possible, therefore our flash drum is designed to dispose a waste stream containing 24.5% siloxane. We discuss the details of sizing and costing in Section 3.

3. Separation Tasks: Sizing and Costs

The separations are carried out in the order most fitting to that laid out by the separation heuristics. The goal of these separation processes is to yield the highest purity acetonitrile and toluene streams while minimizing both cost and waste. Acetonitrile has the lowest boiling point and is separated first, followed by toluene and finally p-xylene.

i. ACN Column

a. Binary Analysis and Operating Pressure

Acetonitrile is the first component separated due its lower boiling point. This separation takes place in a staged packed distillation tower. The column pressure is determined by a binary analysis of acetonitrile and toluene. A higher level of separation is indicated by a greater distance between the equilibrium data and the y=x line.



Figure 3-1: This represents the binary interaction between acetonitrile and toluene. The father the equilibrium line is from the y-x line, the greater the degree of separation.

The x-y diagram above shows that any pressure greater than 0.1 bar will prevent the purity of acetonitrile in the distillate stream from reaching its desired value of 99.82 %. This barrier is due to the azeotrope experienced by the mixture under those system conditions. The azeotrope

composition is raised by adding P-Xylene. Xylene functions as a separating agent, increasing the relative volatility of acetonitrile while simultaneously entraining siloxane in the liquid phase. In order to achieve a vacuum of 0.1 bar, our design uses a liquid ring vacuum pump attached to the total condenser. Sizing information for the vacuum pump is located in Section 4.

b. Column Sizing and Pricing

Our ACN column is a packed column with 1.84m of Sulzer metal gauge packing, type CY with an equivalent of 25 ideal stages. We chose to use packed columns in our design because our columns are too narrow to accommodate stages. The feed is charged to the column on stage 22 with the xylene recycle stream entering on stage 8. The ideal operating temperature ranges from 52.8 C in the bottoms to 21.3 C in the distillate. Under these conditions, a purity of 99.83 % acetonitrile is recovered in the product stream.

A summary of the column one specifications is shown in **Table 3-1** below.

| Acetonitrile Col | umn Specificat | ions | | |
|-----------------------------------|--------------------|----------|--|--|
| Specifications | Acetonitrile Tower | | | |
| Bot. Temperature [°C] | | 52.88 | | |
| Top Temperature [°C] | | 21.30 | | |
| Pressure [bar] | 0.10 | | | |
| Diameter [m] | 0.77 | | | |
| Height [m] | 2.39 | | | |
| Pack Height [m] | 1.84 | | | |
| # of Trays | 23 | | | |
| Equivalent # Stages | 25 | | | |
| Feed-1 | Feed B + C 2 | | | |
| Feed-2 | XyleneRcy | | | |
| Orientation | Vertical | | | |
| Structured Packing Type | CY by Sulzer | | | |
| HETP [m] | 0.08 | | | |
| Material | STANDARD | | | |
| Total Cost [\$] | \$66,470 | | | |
| Distillate Stream Compositions | Species | wt. Frac | | |
| | ACN | 0.9983 | | |
| | TOLUENE | 0.0012 | | |

Table 3-1: Column 1 Specifications

| | P-XYLENE | 0.0005 |
|--------------------------------|----------|----------|
| | SILOXANE | trace |
| Bottoms Stream Compositions | Species | wt. Frac |
| | ACN | |
| | TOLUENE | 0.00121 |
| | P-XYLENE | 0.45646 |
| | SILOXANE | 0.07364 |

The table above lists operating conditions, and the sizing specifics of the distillation tower. The height of the column depended ultimately on the choice of packing material. We chose CY metal gauze packing because it offers a low overall height and is commonly used for vacuum operations. The HETP value of 0.08m is provided graphically by Sulzer; we chose the packing with the lowest possible HETP value that suits vacuum distillation. The height of packing is determined by the following equation:

$$H_{packing} = [\# Theoretical Stages] \cdot [HETP_{packing}]$$
[3-1]

This equation gives us our pack height of 1.84 m. To calculate the column height we add an additional 15% of the pack height to the top and bottom of the column effectively increasing the pack height 30%. This additional height is to account for the space between the packing and the reboiler/condenser at the bottom/top of the column.

$$H_{Column} = 1.3 \cdot H_{packing}$$
[3-2]

This give us our overall height of 2.39 m with a diameter of 0.77m as generated by ASPEN Plus.

The column is priced in EconExpert as a vertically oriented packed tower with the dimensions and operating conditions discussed above. For a packed height of 1.84 m and an operating pressure of 0.1 bar, the material and pressure factors are 4.0 and 1.7 respectively. This gives a base cost of \$8,889 and a total cost, before delivery, of \$60,420.

We will now consider the sizing and thermal duty of the condenser and reboiler.

c. Condenser and Reboiler Sizing

A 4.2 m² total condenser with a heat duty of -160 kW is used to condense the distillate which exits at a rate of $158.2 \frac{kg}{hr}$ at 21.4 °C. The specifications for the condenser and reboiler are shown below.

Table 3-2 ACN Tower Condenser and Reboiler

ACN Column Total Condenser and Partial Reboiler Specifications

| Specifications | R1 | | C1 | |
|--|------------------|---------------------------|---------------------|-------------|
| Area [m ²] | | 3.9 | 4.16 | |
| Duty [kW] | | 185.1 | -160.2 | |
| Туре | kettle | | kettle | |
| | SEP-1 Bottoms | Low Pressur e Steam | SEP-1 Distillate | MEK |
| Pressure in [kPa] | 10 | 172 | 10 | 100 |
| Pressure out [kPa] | 10 | 172 | 10 | 100 |
| Temperature in [°C] | 56 | 115.6 | 21.4 | -29 |
| Temperature Out [°C] | 51.6 | 115.6 | 21.4 | 11.3 4.0 |
| Vapor Fraction In | 0 | 1 | 1 | 0 |
| Vapor Fraction Out | 0.774 | 1 | 0 | 0 |
| Flow rate $\left[\frac{kg}{hr}\right]$ | 2160.5 | 1000 | 711.9 | 7190 |

To size the condensers we use Aspen Plus to generate condenser Hcurves. We use the Hcurves to determine the vapor fraction and temperature leaving the condenser as well as the heat duty required to make the change. We then specify a pseudo-stream as the vapor entering the condenser and connect that stream to a heat exchanger. Varying MEK as the cooling utility we set design specifications to the temperatures and vapor fractions found in the condenser Hcurves.

We use a similar method to size the reboilers. Reboiler Hcurves are generated using Aspen Plus to determine the temperature and vapor fraction leaving the reboiler as well as the heat duty required. A Pseudo-stream is created and used as the liquid entering the reboiler. This Pseudo-stream is fed into a heat exchanger. Using appropriate process steam as the heating utility set the design specifications in accordance with the values found by the reboiler Hcurves. For the Acetonitrile column we calculated a reboiler area of 3.8891 m^2 and a condenser area of 4.16 m^2 .

ii. Toluene Tower

a. Binary Analysis and Operating Pressure

The second separation in our process takes place between toluene and p-xylene. The operating pressure for the toluene tower is determined in the exact same fashion as for the acetonitrile tower. The results from the binary analysis are show below.



Figure 3-2: This represents the binary interaction between acetonitrile and toluene. The father the equilibrium line is from the y-x line, the greater the degree of separation.

b. Column Sizing and Pricing

This column produces 99.92 % toluene product at a rate of 362.8 $\frac{kg}{hr}$. Our Toluene tower is 0.447m in diameter and packed with 4.37m of FLEXIPAC metal packing material type 700Y with an HETP of 0.191m. This packing is equivalent to 24 theoretical stages in a traditional column. Our initial design used the same packing material in both columns but we did not account for the high temperature of column two which would not suit Sulzer type CY packing.

We determine the packed height and column height from equations [3-1] and [3-2] described in the ACN column sizing section. Our toluene column has a diameter of 0.62 m and a height of 4.56. Additional specifications including cost are shown in the table below.

| Toluene Column Specifications | | | |
|-------------------------------|---------------|--|--|
| Specifications | Toluene Tower | | |
| Bot. Temperature [°C] | 137.8 | | |
| Top Temperature [°C] | 109.9 | | |

| Table 3-3. Tolucine Column Cummary |
|------------------------------------|
|------------------------------------|

| Pressure [bar] | 1.00 | | |
|------------------------------------|-----------------|----------|--|
| Diameter [m] | 0.617 | | |
| Height [m] | 4.56 | | |
| Pack Height [m] | 4.37 | | |
| # of Trays | | 21 | |
| Equivalent # Stages | | 23 | |
| Feed 1 Stage | Feed A 8 | | |
| Feed 2 Stage | Bot-1 | 15 | |
| Orientation | Vertical | | |
| Structured Packing Type | 700Y | | |
| HETP [m] | 0.191 | | |
| Material | STANDARD | | |
| Total Cost [\$] | \$99,360 | | |
| Distillate Stream Compositions | Species wt. Fra | | |
| | ACN | 0.00072 | |
| | TOLUENE | 0.99925 | |
| | P-XYLENE | 0.00003 | |
| | SILOXANE | trace | |
| Bottoms Stream Compositions | Species | wt. Frac | |
| | ACN | trace | |
| | TOLUENE | 0.00619 | |
| | P-XYLENE | 0.82978 | |
| | SILOXANE | 0.16403 | |

Koch-Glitsch provides critical sizing information such as the HETP for each packing material. We chose to use 700Y FLEXIPAC because it is the most efficient packing material suited for all applications. The HETP value of 0.191m provided is based on a distillation at total reflux subjected to minor pressure/suction.

The toluene column is priced using EconExpert and is classified as a vertically oriented process vessel with structured packing and an operating pressure of 1.0barg. EconExpert gives a base cost of \$13,280. This cost is then multiplied by the pressure and material factors to give a final cost estimate of approximately \$100,000.

c. Condenser and Reboiler

In addition to the staged packing, the column is also equipped with a total condenser and a partial reboiler. The specifications for each are shown below.

Table 3-4: Toluene Column Condenser and Reboiler Summary

Toluene Column Total Condenser and Partial Reboiler

| Specifications | R2 | | C2 | |
|-------------------------|--------------------------------------|---------|---------------------|------------------|
| Area [m2] | | 5.323 | 2.79 | |
| Duty [kW] | | 169.825 | -165 | |
| Туре | | kettle | kettle | |
| | SEP-2 High Pressure Bottoms Steam | | SEP-2 Distillate | Cooling Water |
| Pressure in [kPa] | 100 | 1033 | 100 | 100 |
| Pressure out [kPa] | 100 | 1033 | 100 | 100 |
| Temperature in [°C] | 137.7 | 181.4 | 109.81 | 35 |
| Temperature Out [°C] | 137.9 | 172.4 | 102 | 99.65 |
| Vapor Fraction In | 0 | 1 | 1 | 0 |
| Vapor Fraction Out | 0.783 | 1 | 0 | 0.074 |
| Flow rate [kg/hr] | 2339 | 13500 | 1632.6 | 2000 |

The sizing process for these reboilers and condensers is the same as the one taken for the ACN reboilers and condensers.

The bottoms stream from this column contains high grade p-xylene and therefore it is favorable to subject the stream to simple flash distillation and recycle the p-xylene back to the acetonitrile tower.

iii. Flash Drum

The final separation is carried out in a flash drum immediately after the toluene separation column. The main function of this flash drum is to return xylene to the first column, and remove the siloxane waste from the original polymerization process.

The exiting stream compositions of the flash drum are highly sensitive to minor changes in flash temperature. We determine the optimum temperature of 138 C with a fraction vaporized of 0.7. Under these operating conditions, the flash drum returns xylene at 86 % purity. This recycle stream is mixed with pure xylene to maintain a constant feed of $100 \frac{kg}{hr}$ to the acetonitrile column. The recycle stream has a flash point of 27.2 °C and must be cooled below this temperature before allowed to enter the mixer.

| Flash Separation of P-Xylene and Siloxane Operating Specifications | | |
|--|--------|--|
| Specifications Flash Drum | | |
| Temperature [°C] | 138.00 | |
| Pressure [bar] | 1.00 | |
| Diameter [m] | 0.15 | |
| Height[m] | 0.48 | |
| Volume [m ³] | 0.01 | |

| | Table 3-5: | Flash | Drum S | Specifications |
|--|------------|-------|--------|----------------|
|--|------------|-------|--------|----------------|

| Heat Duty [kW] | | 7.77 |
|--|--------------|-----------------|
| Material | 316SS | |
| Cost | \$14,581.00 | |
| | Component | Weight Fraction |
| Vapor Stream Compositions (wt.frac.) | Acetonitrile | -trace- |
| | Toluene | 0.0072 |
| | p-Xylene | 0.85 |
| | Water | 0 |
| | Siloxane | 0.14 |
| Liquid Stream Compositions (wt. frac.) | Acetonitrile | -trace- |
| | Toluene | 0.003 |
| | p-Xylene | 0.751 |
| | Water | 0 |
| | Siloxane | 0.245 |

4. Auxiliary Tasks: Sizing and Costing

In addition to the three main separation tasks several auxiliary units are incorporated in this process including:

- i. Vacuum Pump
- ii. Positive Displacement Pumps
- iii. Reflux Drums
- iv. Mixer Motionless, Open Air
- v. Heat Exchangers
- vi. Storage Tanks
- vii. Material of Construction Analysis
 - i. Vacuum Pump

The separation carried out in the first column requires a sub-atmospheric pressure determined by our VLE binary analysis to be 0.1 bar. To pull the vacuum we chose to use a liquid ring pump because they are easy to maintain. Liquid ring pumps only have one moving part, leaving the majority of the mechanical duty to the fluid. To determine the power required to drive the pump we consult pump performance curves provided by Aerstin and Street (1978). The performance curve plots horse power and volume flow rate of the pump versus the suction head. Our design requires 0.9 bar of suction at a volume flow rate of $5.1 \frac{L}{min}$ yielding a 20.4 kW power requirement. The equation below is used to calculate the purchase cost of the liquid-ring pump.

Installed Costs =
$$$28,000 \left[\frac{HP}{10}\right]^{0.5} \cdot \left[\frac{1956}{745}\right]$$
 [4-1]

In the above equation HP represents the power supplied to the fluid in horsepower. The second term in the equation is a corrective factor which adjusts the costs to the proper year. 1956 is the cost index for the current year, 745 was the cost index in 1981. These calculations yield a final estimated pump cost of \$88,600. **Table 4-1** below displays the results of the pump sizing and costing analysis.

| Table 4-1: Vacuum | Pump | Summary |
|-------------------|------|---------|
|-------------------|------|---------|

| Vacuum Pump | | |
|----------------------|-----------------|--|
| Specification Vacuum | | |
| Туре | Liquid Ring | |
| Power [kW] 20 | | |
| Flowrate [I/min] | | |
| Pressure in [bar] 1 | | |
| Pressure out [bar] | | |
| Cost [\$] | \$88,574 | |
| Material | Stainless Steel | |

Table 4-1 is a summary of the sizing and costing analysis conducted for the vacuum pump. We double this cost in our economic analysis to purchase a backup pump that would allow for

continuous production during primary pump maintenance or failure. Stainless Steel and bronze are the materials of choice for liquid-ring pumps as suggested by Aerstin and Street.

ii. Positive Displacement Pumps

The distillate and bottoms streams of column one each require a pump to return the fluid to 1.0 bar of pressure before continuing in the process. Each pump is sized according to its suction pressure and power required. EconExpert gives material and pressure factors of 1.4 and 1.0 respectively, yielding a cost of \$8,880 for each pump. It is not surprising that the cost for each pump is the same as they each operate under the same suction pressure with similar volume flow rates.

| Pump Specification | | | | |
|-----------------------|-----------------------|-----------------------|--|--|
| Specification | Pump 1 | Pump 2 | | |
| Туре | Positive Displacement | Positive Displacement | | |
| Power [kW] | 0.008 | 0.005 | | |
| Flowrate [l/min] | 0.257 | 0.2004 | | |
| Differential Head [m] | 11.10 | 11.64 | | |
| Presure in [bar] | 0.10 | 0.1 | | |
| Pressure out [bar] | 1.00 | 1.00 | | |
| Cost [\$] | \$8,880 | \$8,880 | | |
| Material | Carbon Steel | Carbon Steel | | |

Table 4-2 summarizes the sizing and costing information for each rotary positive displacement pump in our process. As we did for the vacuum pump, we also include backups for each pump.

iii. Reflux Drums

The reflux drums were sized with a holdup time of 8 minutes, at the end of which the reflux would be half full. These drums are considered to be horizontally aligned and are sized according to the volumetric flowrate from each column. Distillate 1 exits at $3.34 \frac{L}{min}$ yielding a volume of $0.24m^3$. In a similar fashion, the second reflux drum is found to have a volume of $7.73m^3$. Each drum is sized with an optimal length to diameter ratio of 3.0. Using this ratio and the volume after 8 minutes, we are able to determine the dimensions of each drum. Table 4-4: Summary of Reflux Drum Sizing

| Reflux Drum Sizing | | | | |
|--------------------|--------|--------|--|--|
| Specification | Drum 1 | Drum 2 | | |
| Diameter [m] | 0.320 | 0.486 | | |
| Length[m] | 0.959 | 1.459 | | |
| Volume [m^3] | 0.2408 | 0.557 | | |
| Flow Rate [l/min] | 3.34 | 7.73 | | |

| Holding Time [min] | 8 | 8 |
|--------------------|--------------|--------------|
| Reflux Ratio | 3.5 | 3.5 |
| Liquid Space [%] | 50 | 50 |
| Cost [\$] | \$4,250 | \$6,700 |
| Material | Carbon Steel | Carbon Steel |

Table 4-4 details each of the reflux drums including their cost. The pricing for these units was carried out in EconExpert. Each reflux drum has a material and pressure factor of 1.0 when carbon-steel is used yielding final costs of \$4,250 and \$6,700 for reflux drums one and two respectively.

iii. Mixer

The mixer in our process is designed to mix the recycled xylene with pure xylene to ensure column one receives a constant supply of separating agent. The ratio of makeup to recycled xylene is controlled in ASPEN Plus with an integrated FORTRAN algorithm. Our mixer of choice was an open top, unstirred mixer with a 70% liquid hold up time of 5 minutes. The mixed stream exits at a rate of $3.94 \frac{L}{min}$ meaning the mixer must be able to hold 19.7L and remain 70% full. We assume a height to diameter ratio of 4 to calculate the dimensions of the mixer. These results are summarized in **Table 4-5** below.

| Mixer 1 | | | | |
|---|----------------------------------|--|--|--|
| Specification | Unstirred, Motionless Mixer | | | |
| Hold Time [min] | 5 | | | |
| Volume [m3] | 0.0142 | | | |
| Diameter [m] | 0.067 | | | |
| | Makeup In Recycle In Recycle Out | | | |
| Pressure [bar] | 1 0.98 1 | | | |
| Temperature [°C] | 20 27 25.11 | | | |
| Mass Flow [^{kg} / _{hr}] | 29.6 81.75 111.4 | | | |
| Cost [\$] | \$1,780 | | | |
| Material | Carbon Steel | | | |

Table 4-5: Unstirred Mixer Sizing

Table 4-5 includes the cost of the mixer at approximately \$1,800 a total purchased cost of \$1,190 and a bare module factor of 1.5.

iv. Heat Exchanger Network

Every exchange of heat that takes place in this process follows the guidelines of the table below. Acetonitrile and toluene have very low flash points and they must be cooled below these temperatures before being exposed to the atmosphere upon entering the storage vessel.

| Product Flash Points | | | | | |
|----------------------|---|----|------|--|--|
| Product Stream | Inlet TempOutlet TempFlash[℃][℃]Point [℃] | | | | |
| ACN | 21.54 | 5 | 5.5 | | |
| TOL | 109.22 | 4 | 4.4 | | |
| Xylene Recycle | 137 | 27 | 27.2 | | |
| WASTE | 137 | 27 | 27.2 | | |

Table 4-6: Outlet Temperatures and Flash Points of Product Streams

Our process uses counter-current shell and tube heat exchangers along with cooling water and MEK, an organic refrigerant. Neither the cooling water nor the MEK may raise more than 10 C above their supply temperatures of 35 °C and -29 C respectively. We set design specifications in ASPEN Plus to control the flowrate of each coolant stream, ensuring that no thermal crossovers took place.

Our initial process flowsheet included seven heat exchangers, incurred more utility cost because each exchanger had its own source of cooling utility. In our optimized design, we add two additional exchangers, one to heat each feed to the 2nd column, effectively reducing the reboiler duty. The waste stream is used to heat both the bottoms stream from the first column (bot-1 feed) as well as Feed 2A.

| Stream Table for Heat Exchanger Network | | | | | | | | | |
|---|---------|-----------------|-----------------|-------------------------------------|---------------------------------|------------------------------------|-------------------------------|--|--|
| Stream | ID | Supply T [C] | Target T [C] | m Flow $\left(\frac{kg}{hr}\right)$ | $Cp\left(\frac{Kj}{kgK}\right)$ | m Cp $\left(\frac{kJ}{hrK}\right)$ | $Q\left(\frac{kJ}{hr}\right)$ | | |
| Dist-1 | SH 1 | 21.39 | 5 | 158.2 | 2.06 | 325.19 | 5329.90 | | |
| Dist-2 | SH 2 | 109.91 | 4 | 362.8 | 2.05 | 742.28 | 78614.62 | | |
| Recycl e | SH 3 | 138 | 27 | 163.57 | 1.63 | 266.27 | 29556.08 | | |
| Waste | SH 4 | 138 | 27 | 248.95 | 1.71 | 424.54 | 47123.52 | | |
| | | | | | | | | | |
| Feed A | SC 1 | 20 | 100 | 270 | 1.658981 | 447.92 | -35833.99 | | |
| Bot-1 | SC 2 | 54 | 64 | 214.4 | 1.80 | 386.17 | -3861.67 | | |
| | | | Cooling Req. | 120928.4 6 | | | | | |

Table 4-7: Hot and Cold Stream Data for HEN Synthesis

Table 4-7 shows the supply and target temperatures of each stream integrated in our heat exchanger network. Our integrated network reduces the cooling required in the system by using the Feed A and Bot-1 to remove 40MJ/hr from the hot streams. This value is determined by summing the total cooling provided by streams SC1 and SC2. It is impossible to cool SH1 with any process stream without violating minimum approach temperatures. A simplified version of our heat exchanger network is shown below in Figure 4-1.



Figure 4-1: This figure depicts our simplified heat exchanger network. The inlet and outlet temperatures of each stream are displayed in Table 4-7. The cooling utilities, CW and MEK, are available at temperature rages of $[35 \ C \ to \ 45 \ C]$ and $[-29 \ C \ to \ -19 \ C]$ respectively.

After completing the HEN we verify our results by comparing the heat duties of the reboilers and condensers after heat integration. These results are outlined in table 4-8 below. Table 4-8: Reboiler and Condenser Heat Duty Comparison

| Heat Integration Results | | | | | | | | | |
|---|-------|-------|--------|--------|--|--|--|--|--|
| Reboiler 1 Reboiler 2 Condenser 1 Condenser 2 | | | | | | | | | |
| Initial Heat Duty [kW] | 185.1 | 200.3 | -162.7 | -166.3 | | | | | |
| Final Heat Duty [kW] | 185 | 169.8 | -160.2 | -165 | | | | | |

The toluene column experienced the largest benefit from the heat integration process, reducing the heat duty approximately 40 kW. Specific information about each heat exchanger is located in Appendix C.

v. Storage Tanks

The cost and size of a storage vessel is directly related to the inlet flowrate, and the desired fill time. Our tanks are designed to reach 50% of their maximum volume after 48 hours of continuous production. To calculate the required volume, we simply multiply the hourly inlet flowrate by 96 hrs to acquire the volume at max capacity.

| Storage Vessel Sizing | | | | | | | | | |
|-----------------------|---|--------------------------|-------------------|----------|--------------|----------|--|--|--|
| Storage Vessel | Inlet Flowrate $\left[\frac{m^3}{day}\right]$ | Volume [m ³] | Pressure [bar] | Material | Туре | Cost | | | |
| Acetonitrile Tank | 4.70 | 18.80 | 1.0 | 316SS | Cone Roof | \$13,880 | | | |
| Toluene Tank | 9.84 | 39.36 | 1.0 | 316SS | Cone Roof | \$19,600 | | | |
| Feed B+C Tank | 1.11 | 29.42 | 1.0 | 316SS | Cone Roof | \$17,000 | | | |
| Feed A Tank | 7.36 | 32.80 | 1.0 | 316SS | Cone Roof | \$18,000 | | | |
| Waste Tank | 0.82 | 4.44 | 1.0 | 316SS | Cone Roof | \$7,456 | | | |
| P-Xylene | 8.20 | 3.28 | 1.0 | 316SS | Cone Roof | \$6,620 | | | |
| Spill Containment | Conditional | 59.04 | 1.0 | 316SS | Cone Roof | \$23,970 | | | |

Table 4-9: Storage Vessels

The final item in Table 4-9 is the spill containment vessel which does not have a set inlet flowrate. This vessel is designed to contain 1.5 time the volume of the largest storage tank to ensure adequate chemical waste storage in the event of equipment failure. Spill containment is discussed in more detail in section 6.

5. Process Economics

i. Delivered Equipment Cos

Each unit in our process is priced based on the EconExpert software package. We use a cost index of 556.7 in this program to ensure that the estimates we gather from EconExpert are appropriate for the current year. EconExpert supplies the total purchased cost as well as two dimensionless factors representing the material and conditions the unit is operating under. We calculate the true cost according to the equation below.

```
[True Cost] = [Base Purchased Cost] * [Material Factor] * [Pressure Factor] [5-1]
```

It is typical for suppliers to provide 'free on board' service to load the equipment for you, excluding the delivery. Design heuristics suggest that the delivered equipment cost should be approximately 10 % greater than the true cost of the product. Table 5-1 below displays the total delivered equipment cost for our process.

| De | Delivered Equipment Costs | | | | | | | | | |
|-------------------|---------------------------|-----|-------|-------------|-----------|--|--|--|--|--|
| Mixer | \$1,700 | 1.0 | 1.0 | \$170 | \$1,900 | | | | | |
| ACN Tower | \$8,900 | 4.0 | 1.7 | \$6,052 | \$66,600 | | | | | |
| TOL Tower | \$13,300 | 4.0 | 1.7 | \$9,044 | \$99,500 | | | | | |
| Reb -1 | \$10,800 | 1.0 | 1.0 | \$1,080 | \$11,900 | | | | | |
| Cond - 1 | \$4,700 | 1.0 | 1.0 | \$470 | \$5,200 | | | | | |
| Reb - 2 | \$10,800 | 1.0 | 1.0 | \$1,080 | \$11,900 | | | | | |
| Cond -2 | \$5,600 | 1.0 | 1.0 | \$560 | \$6,200 | | | | | |
| Pump 1 | \$2,200 | 1.4 | 1.0 | \$308 | \$3,400 | | | | | |
| Pump 2 | \$2,200 | 1.0 | 1.0 | \$220 | \$2,400 | | | | | |
| Vacuum Pump | Costing | Fou | nd ir | n Table 4-1 | \$88,900 | | | | | |
| Reflux Drum 1 | \$3,600 | 1.0 | 1.0 | \$360 | \$4,000 | | | | | |
| Reflux Drum 2 | \$5,000 | 1.0 | 1.0 | \$500 | \$5,500 | | | | | |
| Flash Drum | \$14,600 | 1.0 | 1.0 | \$1,460 | \$16,100 | | | | | |
| Heat Exchangers | \$97,100 | 1.0 | 1.0 | \$9,710 | \$106,800 | | | | | |
| Acetonitrile Tank | \$13,900 | 1.0 | 1.0 | \$1,390 | \$15,300 | | | | | |

Table 5-1: Total Delivered Equipment Cost

| Toluene Tank | \$19,600 | 1.0 | 1.0 | \$1,960 | \$21,600 |
|-------------------|--------------|-----|-------|-------------|-----------|
| Feed B+C Tank | \$17,100 | 1.0 | 1.0 | \$1,710 | \$18,800 |
| Feed A Tank | \$18,000 | 1.0 | 1.0 | \$1,800 | \$19,800 |
| Waste Tank | \$7,500 | 1.0 | 1.0 | \$750 | \$8,300 |
| P-Xylene | \$6,600 | 1.0 | 1.0 | \$660 | \$7,300 |
| Spill Containment | \$24,000 | 1.0 | 1.0 | \$2,400 | \$26,400 |
| Backup Pump 1 | \$2,200 | 1.4 | 1.0 | \$308 | \$3,400 |
| Backup Pump 2 | \$2,200 | 1.0 | 1.0 | \$220 | \$2,400 |
| Bkp Vc Pump | Costing Foun | | nd ir | n Table 4-1 | \$88,900 |
| | | | | Total Cost | \$532,500 |

In this table each heat exchanger is combined into a single cost as each exchanger costs exactly the same when sized in EconExpert. A simple summation gives our total delivered equipment cost (DEC). The DEC is an important value for the remaining economic analysis, it is used to determine the necessary investments in terms of fixed capital and operation costs.

I. Fixed Capital Investment

To determine the fixed capital investment (FCI) for our process, we must calculate the direct, indirect, and contracting costs. Each cost in the subsequent table is based off of a percentage of the delivered equipment cost, and is subject to alteration by the engineer in charge of the process, within reason. Certain line items are excluded from our analysis because we are adding on to an existing plant. The land, service facilities, and buildings are already supplied by the company we are working for and therefore can be excluded from our total direct plant cost.

| Install Costs | | | | | | | |
|---------------------------------|------------------|------------------------|-------------|--|--|--|--|
| Direct Production Costs | [%] DEC | | Value | | | | |
| | | | | | | | |
| Delivered Equipment Cost | | 100 | \$515,769 | | | | |
| Installation | | 47 | \$242,411 | | | | |
| Piping | | 66 | \$340,407 | | | | |
| Instrumentation and Controls | | 15 | \$77,365 | | | | |
| Electrical | | 11 | \$56,735 | | | | |
| Yard Improvements | | 5 | \$25,788 | | | | |
| | To Dir Pla | tal ect ant Cost | \$1,258,476 | | | | |
| | i | | | | | | |

| Indirect Costs | [%] DEC | Value |
|-------------------------|-------------------|-----------|
| Engineering Supervision | 35 | \$180,519 |
| Construction Expenses | 45 | \$232,096 |
| | Total Indirect | \$412,615 |
| | | |
| Other | [%] DEC | Value |
| Contractor's Fee | 21 | \$108,311 |
| Contingency | 42 | \$216,623 |
| | Total Other | \$324,934 |

This table shows the cost of each service/improvement as compared to the DEC. We acquire the [%] DEC values from Peters and Timmerhaus (1981). Finally our FCI is calculated by adding up the Direct, Indirect, and Other costs to yield a value of \$1,996,000.

| Table 5-3: | Summary c | of Key | Investment | Figures |
|-------------|-----------|--------|------------|---------|
| 1 4010 0 01 | | | | |

| Capital Investment Summary | | | | | |
|-------------------------------|-------------|--|--|--|--|
| DEC | \$515,800 | | | | |
| FCI | \$1,996,000 | | | | |
| WCI | \$443,600 | | | | |
| тсі | \$2,439,600 | | | | |

Table 5-3 summarizes the delivered equipment costs, fixed capital investment, working capital investment, and total capital investment.

III. Labor

Human labor is essential to the day-to-day operation of the plant, therefore we decided to hire

several at an hourly rate of \$25/hr for a total of 2000 hours/yr. $Labor Cost = \left[2000 \frac{hrs}{worker \cdot year}\right] * [\# Workers] \cdot \left[\frac{\$}{hr}\right] \cdot [1.7] \quad [Eq 5-1]$ In addition to their \$25/hr each worker will receive an additional 70% in benefits leaving us with a total labor cost of \$680,000 annually.

IV. Manufacturing Cost

The manufacturing cost of this process takes into account periodic maintenance, required operating supplies, and laboratory charges. These are considered direct costs in the

manufacturing process but in order to fully estimate the manufacturing cost, one must account for addition fixed costs, general expenses, and the plant overhead fees. The following table summarizes the cost of manufacturing on a yearly basis. All line items are from Peters and Timmerhaus (1991) for fluid processing plants.

| Manufacturing Cost | | | | | | |
|--------------------------|-----|------------------------------------|-----------|--|--|--|
| Direct Costs | [%] | Percentage of | Value | | | |
| Maintenance | 6 | FCI | \$119,700 | | | |
| Operating Supplies | 15 | FCI | \$299,400 | | | |
| Laboratory Charges | 15 | Operating Labor | \$102,000 | | | |
| Fixed Charges | | | | | | |
| Local Taxes | 2.5 | FCI | \$49,900 | | | |
| Insurance | 0.7 | FCI | \$13,900 | | | |
| Plant Overhead 55 | | Labor, Supervision, Maintenance | \$539,100 | | | |
| General Expenses | | | | | | |
| Administrative Costs | 15 | Labor, Supervision, Maintenance | \$147,000 | | | |
| Distribution and Selling | 15 | Manufacturing cost | \$168,600 | | | |

Table 5-4: Calculation of Manufacturing Cost

The manufacturing cost of a product plays into the operation cost of the plant and ultimately the rate of return.

V. Rate of Return

The rate of return is based on the after tax cash flow of the process. We determine this cash flow by following a 20 year SOYD depreciation scheme, assuming a salvage value of 0. This analysis also includes a 10% increase in operating cost during the first year to account for startup and any additional costs it may bring with it. The results of this analysis are displayed below.

Table 5-5: Cash Flow Analysis

| | 20 Year SOYD Cash Flow Analysis | | | | | | | | |
|----------|---------------------------------|-----------------------|-------------------------|--------------------------------|-------------------|-----------------|------------------------|--|--|
| Yea r | Total Product Cost | Revenue From Sales | Before Tax Cash Flow | SOYD Depreciatio n Value | Taxable Income | Income Taxes | After Tax Cash Flow | | |
| 0 | -\$2,518,700 | | | | | | -\$2,518,700 | | |

| 1 | \$3,935,900 | \$9,679,800 | \$5,743,900 | \$203,897 | \$5,540,003 | \$2,216,001 | \$3,527,900 |
|----|-------------|--------------|-------------|-----------|-------------|-------------|-------------|
| 2 | \$3,578,100 | \$9,679,800 | \$6,101,700 | \$193,702 | \$5,907,998 | \$2,363,199 | \$3,738,500 |
| 3 | \$3,578,100 | \$9,679,800 | \$6,101,700 | \$183,507 | \$5,918,193 | \$2,367,277 | \$3,734,400 |
| 4 | \$3,578,100 | \$9,679,800 | \$6,101,700 | \$173,312 | \$5,928,388 | \$2,371,355 | \$3,730,300 |
| 5 | \$3,578,100 | \$9,679,800 | \$6,101,700 | \$163,117 | \$5,938,583 | \$2,375,433 | \$3,726,300 |
| 6 | \$3,578,100 | \$9,679,800 | \$6,101,700 | \$152,923 | \$5,948,777 | \$2,379,511 | \$3,722,200 |
| 7 | \$3,578,100 | \$9,679,800 | \$6,101,700 | \$142,728 | \$5,958,972 | \$2,383,589 | \$3,718,100 |
| 8 | \$3,578,100 | \$9,679,800 | \$6,101,700 | \$132,533 | \$5,969,167 | \$2,387,667 | \$3,714,000 |
| 9 | \$3,578,100 | \$9,679,800 | \$6,101,700 | \$122,338 | \$5,979,362 | \$2,391,745 | \$3,710,000 |
| 10 | \$3,578,100 | \$9,679,800 | \$6,101,700 | \$112,143 | \$5,989,557 | \$2,395,823 | \$3,705,900 |
| 11 | \$3,578,100 | \$9,679,800 | \$6,101,700 | \$101,948 | \$5,999,752 | \$2,399,901 | \$3,701,800 |
| 12 | \$3,578,100 | \$9,679,800 | \$6,101,700 | \$91,754 | \$6,009,946 | \$2,403,979 | \$3,697,700 |
| 13 | \$3,578,100 | \$9,679,800 | \$6,101,700 | \$81,559 | \$6,020,141 | \$2,408,057 | \$3,693,600 |
| 14 | \$3,578,100 | \$9,679,800 | \$6,101,700 | \$71,364 | \$6,030,336 | \$2,412,134 | \$3,689,600 |
| 15 | \$3,578,100 | \$9,679,800 | \$6,101,700 | \$61,169 | \$6,040,531 | \$2,416,212 | \$3,685,500 |
| 16 | \$3,578,100 | \$9,679,800 | \$6,101,700 | \$50,974 | \$6,050,726 | \$2,420,290 | \$3,681,400 |
| 17 | \$3,578,100 | \$9,679,800 | \$6,101,700 | \$40,779 | \$6,060,921 | \$2,424,368 | \$3,677,300 |
| 18 | \$3,578,100 | \$9,679,800 | \$6,101,700 | \$30,585 | \$6,071,115 | \$2,428,446 | \$3,673,300 |
| 19 | \$3,578,100 | \$9,679,800 | \$6,101,700 | \$20,390 | \$6,081,310 | \$2,432,524 | \$3,669,200 |
| 20 | \$3,578,100 | \$10,137,700 | \$6,559,600 | \$10,195 | \$6,549,405 | \$2,619,762 | \$3,939,800 |

The after tax cash flow, ATCF, is the most important column for calculating the rate of return on our initial investment. From this cash flow we calculate an annual rate of return of 144%. These values are based off of the 1981 cost index written by Peters and Timmerhaus. Based on this rate of return we can confidently recommend operating this solvent recovery system under the operating specifications displayed in the Equipment Summary.

The success of our process is ultimately dependent on the market price of acetonitrile and toluene. We conduct a sensitivity analysis on the rate of return to examine its behavior as the market varies. The following plot displays the response of the rate of return when the product prices are changed.



Figure 5-1: Sensitivity Analysis on the Rate of Return

According to figure 5-1, our profits are highly dependent on the price of toluene. This plot was generated using Excel and by varying each product price while holding the other constant at the value given in the design specifications.

6. Safety and quality control

The proposed recycle process involves a variety of hazardous materials and operating conditions that must be avoided through the design of a safe plant process. The first things to consider are the hazardous materials used in the process. Acetonitrile, Toluene, and Xylene have flash temperatures of 4.4, 5.5, and 27 $\,^{\circ}C$ respectively. Unfortunately the mixer we use that contains mostly xylene is an open air mixer, and both the Acetonitrile and Toluene storage tanks are open to the atmosphere. We must cool these streams below their flash points before they can be stored or mixed. We consider all possibilities of failure along with the consequence of that failure. Failure Mode and Effects Analysis (FMEA) and Hazard Operability Analysis (HAZOP) are the preferred methods of risk assessment. FMEA is focused on how equipment failure affects the safety of the process and the economic impact. HAZOP is similar to FEMA, but focuses on safety in regards to personnel, the environment, and the safeguards that are necessary in order for the process to run smoothly. We increase the overall safety of the process by compiling widely accepted methods of systematic safety assessment: HAZOP, FMEA, and an inherently safer design checklist.

i. Spill Containment

In the event of spillage, it is important to have a vessel large enough to contain the equivalent volume of the largest tank plus an additional 50% of that value. This ensures that even if our largest tank experiences failure, we will still be able to prevent the effluent fluids from exiting the plant. Our largest storage tank contains the toluene product and is $39 m^3$ leading to a containment vessel with a volume of $59 m^3$. In addition to containing the fluid in the drains, we must absorb the pooling liquids with a porous, inert material such as vermiculite. Above all else, we must be sure that all drainage is clear from all sources of ignition.

ii. Fire Prevention

As mentioned previously Acetonitrile and toluene both have flash points below room temperature. Meaning a rupture in any of the networks containing Toluene or Acetonitrile could be a dangerous situation for surrounding personnel and equipment. The system of controllers explained in the P&ID diagram are the first line of defense, and should be designed to warn operators of data inconsistencies in the system. These inconsistencies could signify a leak or rupture in the system or possibly a hot flammable stream that is not cooled enough. In the case these controllers somehow fail additional passive and active prevention techniques will need to be installed. A passive solution could entail isolating the exits of the flammable streams in the design of the chemical plant from any spark sources. Conventional water spray systems will not extinguish flames made by a low flash point material. Acetonitrile can be extinguished using Bromochlorodifluoromethane (BCF). Acetonitrile can be extinguished by CO₂ portable extinguishers. The implementation of mobile foam monitors around the ACN and Toluene storage tanks as a last line of active fire protection.

iii. Maximum Allowable operating Conditions

The maximum allowable pressure and temperature of each unit are determined using heuristics as guidelines. The maximum allowable pressure is either 1.1 times the operating pressure, or 3.47 bar higher than the operating pressure, whichever gives a higher value. By these guidelines no vessel should exceed 4.5 bars of pressure at any point in our process. Table 6-1: MAWP/MAWT Summary

| | Operating Pressure [bar] | MAWP [bar] | MAWT [C] |
|-------------------|--------------------------------|---------------|-------------|
| Mixer | 1 | 4.447 | 315.6 |
| ACN Tower | 0.1 | 3.547 | 315.6 |
| TOL Tower | 1 | 4.447 | 315.6 |
| Reb -1 | 0.1 | 3.547 | 315.6 |
| Cond - 1 | 0.1 | 3.547 | 315.6 |
| Reb - 2 | 1 | 4.447 | 315.6 |
| Cond -2 | 1 | 4.447 | 315.6 |
| Pump 1 | 0.1 | 3.547 | 315.6 |
| Pump 2 | 0.1 | 3.547 | 315.6 |
| Vacuum Pump | 0.1 | 3.547 | 315.6 |
| Reflux Drum 1 | 0.1 | 3.547 | 315.6 |
| Reflux Drum 2 | 1 | 4.447 | 315.6 |
| Flash Drum | 1 | 4.447 | 315.6 |
| Heat Exchangers | 1 | 4.447 | 315.6 |
| Acetonitrile Tank | 1 | 4.447 | 315.6 |
| Toluene Tank | 1 | 4.447 | 315.6 |
| Feed B+C Tank | 1 | 4.447 | 315.6 |
| Feed A Tank | 1 | 4.447 | 315.6 |
| Waste Tank | 1 | 4.447 | 315.6 |
| P-Xylene | 1 | 4.447 | 315.6 |
| Spill Containment | 1 | 4.447 | 315.6 |
| Backup Pump 1 | 0.1 | 3.547 | 315.6 |
| Backup Pump 2 | 0.1 | 3.547 | 315.6 |
| Bkp Vc Pump | 0.1 | 3.547 | 315.6 |

Table 6-1 above displays the maximum limits for each unit. The maximum temperature for each unit is the same because no unit exceed the limit of 315.6 C given by the design heuristic. The MAWP is very important to plant safety. The understanding of this limit helps reduce the chance of explosion due to overpressure.

iv. HAZOP

List of chemicals involved in the proposed process are as follows:

- Acetonitrile (ACN)
- MethylEthylKetone (MEK)
- Siloxane
- Toluene
- Water
- P-Xylene

Potential Hazards:

Three of the main components that are being separated, Toluene, Acetonitrile, and p-Xylene, are exposed to temperatures above their flash points during the recycling process. Separation processes are also innately are run at high temperatures, relative to room temperature, to ensure sharp separations. Two of these components, Toluene and Acetonitrile have flash points of 5 and 4 °C respectively which are well below room temperature.

Analysis Boundaries:

- 1. Incidents that occur during the repair or maintenance process are not included.
- 2. Feeds enter the recycle process directly from the siloxane polymerization plant at a set steady flow rate that is closed from the atmosphere.
- 3. Cooling water and MEK flow rates are driven by gravity, and tuned using a control valve.
- 4. Stead-state operation
- 5. Equipment is well built and use as designed
- 6. Operators are properly trained
- 7. Procedures are clearly written
- 8. Maintenance and inspections are performed routinely

Analysis Results:

Strict enforcement of MSDS approved PPE, proper and relevant operator training as well as an emphasis on workplace safety. Any stream containing a material above its flash point must have temperature sensors as well as a pressure or a flow rate sensor to ensure there is no leak. Streams around heat exchangers should also be equipped with temperature and flow sensors to ensure there is no cross flow and the correct amount of heat is being exchanged. Extensive tables for the HAZOP analysis are located in Appendix –D

v. Personal Protective Equipment

The safety data sheets described above outline the PPE requirements for all personnel who could potentially come in contact with hazardous materials. To ensure proper operator safety we require that gloves, insulated boots, full body suits, and safety glasses must be worn at all times. In the event that an operator must handle the materials directly, they are required to adorn addition protective equipment such as a self-contained respirator or breathing apparatus

Acetonitrile

Acetonitrile is highly flammable in its vapor state, and is flammable under room temperature at atmospheric pressure. Acetonitrile may also cause serious eye and skin irritation as well as toxic effects when inhaled or ingested. The use of personal protective equipment such as safety glasses, breathing apparatus, gloves, and lab coats should be required.

If personnel's eyes come in contact, rinse out eye for at least 15 minutes. If personnel's skin comes in contact with Acetonitrile wash the afflicted area with soap and water for at least 15 minutes. In the case of serious inhalation evacuate the afflicted personnel to a safe area with haste. Loosen any tight clothing collar, tie, belt or waistband. If breathing is difficult, administer oxygen. If the victim is not breathing, preform CPR (WARNING: It may be hazardous to the person providing aid to give mouth-to-mouth resuscitation when the inhaled material is toxic, In this case use a bag valve mask). In case of ingestion do not induce vomiting unless directed to do so by a medical professional. Never give anything by mouth to an unconscious person. Loosen any tight clothing and get medical attention if any symptoms appear.

The storage of acetonitrile must be in a tight ventilated container that is isolated from any heat or spark sources. In case of spill avoid contamination into the environment, and upgrade the level of personal protective equipment to a full body suit, self-contained breathing apparatus, vapor respirator, boots, and gloves. Provide exhaust ventilation or other engineering controls to keep the airborne concentrations of vapors below their respective threshold limit value. Ensure that eyewash stations and safety showers are proximal to the work-station location.

Toluene

Toluene is highly flammable as a vapor, hazardous to aquatic life, a skin irritant, can incur serious eye and organ damage, and may cause death if inhaled. Personal protective equipment such as a breathing apparatus, gloves, and eyewear should be required in operations involving toluene.

If skin comes in contact with toluene the MSDS procedure states to wash the affected area with soap and water for at least 20 minutes. If personnel's eyes come in contact, rinse out eye for at least 15 minutes, and seek medical attention immediately. In the case of serious inhalation evacuate the afflicted personnel to a safe area with haste. Loosen any tight clothing collar, tie, belt or waistband. If breathing is difficult, administer oxygen. If the victim is not breathing, preform CPR (WARNING: It may be hazardous to the person providing aid to give mouth-to-mouth resuscitation when the inhaled material is toxic, In this case use a bag valve mask). In case of ingestion do not induce vomiting unless directed to do so by a medical professional. Never give anything by mouth to an unconscious person. Loosen any tight clothing and get medical attention if any symptoms appear.

Toluene needs to be stored in a sealed, well ventilated storage vessel that is isolated from any ignition sources. Drains and surface water must be protected from potential spills to avoid contamination. In case of spill avoid contamination into the environment, and upgrade the level of personal protective equipment to a full body suit, self-contained breathing apparatus, vapor respirator, boots, and gloves. Non sparking materials must be used in the cleanup of toluene. Provide exhaust ventilation or other engineering controls to keep the airborne concentrations of

vapors below their respective threshold limit value. Ensure that eyewash stations and safety showers are proximal to the work-station location.

P-Xylene

The MSDS lists p-xylene as a flammable liquid and vapor, hazardous to aquatic life, and harmful when in contact with skin and eyes, and has a toxicity when inhaled or ingested. In case of contact with eyes flush with plenty of water for at least 15 minutes and seek medical attention if serious irritation persists. In the case of skin contact flush the afflicted area with an excess of water. Cover skin with an emollient, and remove any contaminated clothing and shoes. Thoroughly wash clothing and shoes before reuse. In the case of serious inhalation evacuate the afflicted personnel to a safe area with haste. Loosen any tight clothing collar, tie, belt or waistband. If breathing is difficult, administer oxygen. If the victim is not breathing, preform CPR (WARNING: It may be hazardous to the person providing aid to give mouth-to-mouth resuscitation when the inhaled material is toxic, In this case use a bag valve mask). In case of ingestion do not induce vomiting unless directed to do so by a medical professional. Never give anything by mouth to an unconscious person. Loosen any tight clothing and get medical attention if any symptoms appear.

P-Xylene should be stored in a sealed, well ventilated storage vessel that is isolated from any ignition sources. Drains and surface water must be protected from potential spills to avoid contamination. In case of spill avoid contamination into the environment, and upgrade the level of personal protective equipment to a full body suit, self-contained breathing apparatus, vapor respirator, boots, and gloves. Non sparking materials must be used in the cleanup of p-xylene. Provide exhaust ventilation or other engineering controls to keep the airborne concentrations of vapors below their respective threshold limit value. Ensure that eyewash stations and safety showers are proximal to the work-station location

7. Conclusion

The recovery of solvents, toluene and acetonitrile, from a polymerization plant is best carried out using two distillation towers and one flash drum. Our process utilizes the packed columns to separate out the solvents independently while the flash drum separates the waste from recycled separating agent. The results from or HAZOP and FMEA analyses allow us to confidently present a safe design for the solvent recovery. Not only is our process efficient, it also generates a large savings value.

Our process generates a 144% rate of return on a total investment of \$2.52 million with an annual after tax cash flow of approximately \$3.7 million. Sensitivity analysis on the rate of return determined that our process will remain profitable as long as the pure component prices remain above \$1 per kilogram. If further adjustments were to be made to our design, we would recommend integration of the column one feed into our heat exchanger network.

Thank you for the opportunity to work on this design project, feel free to contact us with any question or concerns you may have.
Appendix A: Stream Tables

i. Table A-1 – Stream Table Part 1

| | ACN-PROD | BOT-1 | BOT-1H | BOT-1P | BOT-2 | CW-C2 | CW-C4 | CW-H2 |
|------------------|-----------|-----------|-----------|-----------|----------|----------|----------|----------|
| From | | P-1 | 2-Sep | E-4B | FLASH-1 | E2-A | E4 | |
| То | E1 | 1-Sep | E-4B | P-1 | 2-Sep | | | E2-A |
| Substream: MIXED | | | | | | | | |
| Mass Flow kg/hr | | | | | | | | |
| ACN | 157.9412 | 0.2587969 | 0.2587969 | 0.2587969 | 1.62E-11 | 0 | | |
| TOLUENE | 0.1883581 | 97.32374 | 97.32374 | 97.32374 | 0.744797 | 0 | | |
| P-XYLENE | 0.0704428 | 99.92956 | 99.92956 | 99.92956 | 99.91296 | 0 | 0 | 0 |
| WATER | 0 | 0 | 0 | 0 | 0 | 940.7379 | 0 | 0 |
| MEK | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SILOXANE | 3.22E-22 | 15.70086 | 15.70086 | 15.70086 | 19.75072 | 0 | 42.05953 | 940.7379 |
| Mass Frac | | | | | | | 0 | 0 |
| ACN | 0.9983641 | 1.21E-03 | 1.21E-03 | 1.21E-03 | 1.34E-13 | 0 | 0 | 0 |
| TOLUENE | 1.19E-03 | 0.4564626 | 0.4564626 | 0.4564626 | 6.19E-03 | 0 | | |
| P-XYLENE | 4.45E-04 | 0.4686843 | 0.4686843 | 0.4686843 | 0.829784 | 0 | 0 | 0 |
| WATER | 0 | 0 | 0 | 0 | 0 | 1 | 0 | 0 |
| MEK | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| SILOXANE | 2.03E-24 | 0.0736393 | 0.0736393 | 0.0736393 | 0.164031 | 0 | 1 | 1 |
| Total Flow kg/hr | 158.2 | 213.213 | 213.213 | 213.213 | 120.4085 | 940.7379 | 0 | 0 |
| Vapor Frac | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Liquid Frac | 1 | 1 | 1 | 1 | 1 | 1 | 42.05953 | 940.7379 |
| Solid Frac | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Temperature C | 5 | 53.87832 | 63.90875 | 53.90486 | 138.2141 | 35 | 1 | 1 |
| Pressure bar | 1 | 0.1 | 1 | 1 | 1 | 1 | 0 | 0 |
| Enthalpy Btu/lb | 311.0895 | -53.86925 | -45.97711 | -53.81416 | -112.976 | -6802.71 | 35 | 45.00039 |

ii. Table A-2 – Stream Table Part 2

| | CW-H4 | DIST-1 | DIST-1P | DIST-2 | FEED-1 | FEED-2A | FEED2A-C | FEED2A-H | WASTE-H3 |
|------------------|----------|----------|----------|----------|----------|---------|----------|----------|----------|
| From | | PUMP2 | E1 | E3-A | 1-Sep | 2-Sep | E3-A | E4-A | E4 |
| То | E4 | 1-Sep | PUMP2 | 2-Sep | | E4-A | | E3-A | E-4B |
| Substream: MIXED | | | | | | | | | |
| Mass Flow kg/hr | | | | | | | | | |
| ACN | | | | | | | | | |
| TOLUENE | | | | | | | | | |
| P-XYLENE | 0 | 157.9412 | 157.9412 | 0.261136 | 158.2 | 0 | 0 | 0 | 7.77E-13 |
| WATER | 0 | 0.188358 | 0.188358 | 362.5272 | 96.9 | 265.95 | 265.95 | 265.95 | 0.132707 |
| МЕК | 0 | 0.070443 | 0.070443 | 0.0117 | 0 | 0 | 0 | 0 | 29.53713 |
| SILOXANE | 42.05953 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Mass Frac | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| ACN | 0 | 3.22E-22 | 3.22E-22 | 2.29E-06 | 4.9 | 4.05 | 4.05 | 4.05 | 8.949852 |
| TOLUENE | | | | | | | | | |
| P-XYLENE | 0 | 0.998364 | 0.998364 | 7.20E-04 | 0.608462 | 0 | 0 | 0 | 2.01E-14 |
| WATER | 0 | 1.19E-03 | 1.19E-03 | 0.999248 | 0.372692 | 0.985 | 0.985 | 0.985 | 3.44E-03 |
| MEK | 0 | 4.45E-04 | 4.45E-04 | 3.22E-05 | 0 | 0 | 0 | 0 | 0.764821 |
| SILOXANE | 1 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Total Flow kg/hr | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Vapor Frac | 0 | 2.03E-24 | 2.03E-24 | 6.31E-09 | 0.018846 | 0.015 | 0.015 | 0.015 | 0.231743 |
| Liquid Frac | 42.05953 | 158.2 | 158.2 | 362.8 | 260 | 270 | 270 | 270 | 38.61969 |
| Solid Frac | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Temperature C | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| Pressure bar | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Enthalpy Btu/lb | 44.99976 | 21.39113 | 21.54418 | 109.8909 | 20 | 100 | 20 | 97.96897 | 70.64693 |
| Entropy Btu/lb-R | 1 | 0.1 | 1 | 1 | 1 | 1 | 1 | 1 | 0.955735 |
| Average MW | -6784.8 | 325.2858 | 325.4519 | 125.445 | 207.1597 | 104.378 | 41.38287 | 102.6347 | -214.947 |

iii. Table A-3 – Stream Table Part 3

| | H-WASTE1 | H-WASTE2 | H-WASTE4 | MAKEUP | MEK-IN1 | MEK-IN2 | MEK-IN4 | MEK-OUT1 | XYL-RCY |
|------------------|----------|----------|----------|----------|----------|----------|----------|----------|----------|
| From | E4-A | E-4B | E4-D | Mixer | E1 | E2-B | E4-D | | 1-Sep |
| То | FLASH-1 | E4-A | E4 | | | | | E1 | MIX-RCYC |
| Substream: MIXED | | | | | | | | | |
| Mass Flow kg/hr | | | | | | | | | |
| ACN | | | | | | | | | |
| TOLUENE | | | | | | | | | |
| P-XYLENE | 7.77E-13 | 7.77E-13 | 7.77E-13 | 0 | 0 | 0 | 0 | 0 | 1.54E-11 |
| WATER | 0.132707 | 0.132707 | 0.132707 | 0 | 0 | 0 | 0 | 0 | 0.61209 |
| MEK | 29.53713 | 29.53713 | 29.53713 | 29.62417 | 0 | 0 | 0 | 0 | 100 |
| SILOXANE | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Mass Frac | 0 | 0 | 0 | 0 | 280 | 330 | 1689.806 | 280 | 0 |
| ACN | 8.949852 | 8.949852 | 8.949852 | 0 | 0 | 0 | 0 | 0 | 10.80086 |
| TOLUENE | | | | | | | | | |
| P-XYLENE | 2.01E-14 | 2.01E-14 | 2.01E-14 | 0 | 0 | 0 | 0 | 0 | 1.38E-13 |
| WATER | 3.44E-03 | 3.44E-03 | 3.44E-03 | 0 | 0 | 0 | 0 | 0 | 5.49E-03 |
| MEK | 0.764821 | 0.764821 | 0.764821 | 1 | 0 | 0 | 0 | 0 | 0.897562 |
| SILOXANE | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Total Flow kg/hr | 0 | 0 | 0 | 0 | 1 | 1 | 1 | 1 | 0 |
| Vapor Frac | 0.231743 | 0.231743 | 0.231743 | 0 | 0 | 0 | 0 | 0 | 0.096944 |
| Liquid Frac | 38.61969 | 38.61969 | 38.61969 | 29.62417 | 280 | 330 | 1689.806 | 280 | 111.413 |
| Solid Frac | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Temperature C | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 |
| Pressure bar | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Enthalpy Btu/lb | 137 | 123.0842 | 45 | 20 | -29 | -29 | -29 | -19.2409 | 25.11668 |
| Entropy Btu/lb-R | 0.955735 | 0.955735 | 0.955735 | 1 | 1 | 1 | 1 | 1 | 1 |
| Average MW | -159.492 | -171.68 | -234.447 | -102.209 | -1677.49 | -1677.49 | -1677.49 | -1669.38 | -160.735 |

| | MEK-OUT2 | MEK-OUT3 | MEK-OUT4 | RECYC-1 | RECYC-2 | RECYC-3 | TOL-HOT | TOL-PROD |
|------------------|----------|----------|----------|----------|----------|----------|----------|----------|
| From | | | E3-B | E2-A | E2-B | Mixer | E3-B | |
| То | E2-B | E3-B | E4-D | FLASH-1 | E2-A | E2-B | E3-A | E3-B |
| Substream: MIXED | | | | | | | | |
| Mass Flow kg/hr | | | | | | | | |
| ACN | | | | | | | | |
| TOLUENE | | | | | | | | |
| P-XYLENE | 0 | 0 | 0 | 1.54E-11 | 1.54E-11 | 1.54E-11 | 0.26113 | 0.26113 |
| WATER | 0 | 0 | 0 | 0.61209 | 0.61209 | 0.61209 | 362.527 | 362.527 |
| MEK | 0 | 0 | 0 | 70.37583 | 70.37583 | 70.37583 | 0.0117 | 0.0117 |
| SILOXANE | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Mass Frac | 330 | 1689.806 | 1689.806 | 0 | 0 | 0 | 0 | 0 |
| ACN | 0 | 0 | 0 | 10.80086 | 10.80086 | 10.80086 | 2.29E-06 | 2.29E-06 |
| TOLUENE | | | | | | | | |
| P-XYLENE | 0 | 0 | 0 | 1.88E-13 | 1.88E-13 | 1.88E-13 | 7.20E-04 | 7.20E-04 |
| WATER | 0 | 0 | 0 | 7.48E-03 | 7.48E-03 | 7.48E-03 | 0.999248 | 0.999248 |
| MEK | 0 | 0 | 0 | 0.860458 | 0.860458 | 0.860458 | 3.22E-05 | 3.22E-05 |
| SILOXANE | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Total Flow kg/hr | 1 | 1 | 1 | 0 | 0 | 0 | 0 | 0 |
| Vapor Frac | 0 | 0 | 0 | 0.132058 | 0.132058 | 0.132058 | 6.31E-09 | 6.31E-09 |
| Liquid Frac | 330 | 1689.806 | 1689.806 | 81.78879 | 81.78879 | 81.78879 | 362.8 | 362.8 |
| Solid Frac | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 0 |
| Temperature C | 1 | 1 | 1 | 0 | 1 | 1 | 1 | 1 |
| Pressure bar | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Enthalpy Btu/lb | -25.0352 | -18.993 | -28.6394 | 137 | 45 | 27 | 55 | 4 |
| Entropy Btu/lb-R | 1 | 1 | 1 | 0.955735 | 0.955735 | 0.955735 | 1 | 1 |
| Average MW | -1674.21 | -1669.17 | -1677.19 | 37.27103 | -168.686 | -181.933 | 79.86073 | 42.48466 |

Appendix B: Main Process Flowsheet



Figure B-1: Main process flow sheet as generated by ASPEN Plus V8.8

Appendix C: Equipment Summary

I. Distillation Column Summary

| RADFRAC | Specificati | ons | | | |
|--------------------------------|--------------|-------------|--------------|---------------|--|
| Specifications | Acetonitril | e Tower | Toluen | e Tower | |
| Bot. Temperature [°C] | | 52.88 | 137. | | |
| Top Temperature [°C] | | 21.30 | | 109.9 | |
| Pressure [bar] | | 0.10 | | 1 | |
| Diameter [m] | | 0.77 | | 0.617 | |
| Height [m] | | 2.39 | | 4.56 | |
| Pack Height [m] | | 1.84 | | 4.37 | |
| # of Trays | | 23 | | 21 | |
| # Stages | | 23 | | 23 | |
| Feed-1 | | 22 | Feed A | 8 | |
| Feed-2 | XYLRCY | 8 | Bot-1 | 15 | |
| Orientation | Verti | cal | Ver | tical | |
| Structured Packing Type | CY by S | Sulzer | 700Y F | 700Y FlexiPac | |
| HETP [m] | 0.0 | 8 | 0.191 | | |
| Material | STANE | DARD | STANDARD | | |
| Total Cost [\$] | | \$66,467 | \$99,357 | | |
| Distillate Stream Compositions | Species | wt. Frac | Species | wt. Frac | |
| | ACN | 0.99836 | ACN | 0.00072 | |
| | TOLUEN E | 0.00119 | TOLUEN E | 0.99925 | |
| | P- XYLENE | 0.00045 | P- XYLENE | 0.00003 | |
| | SILOXAN E | trace- | SILOXAN E | trace | |
| Bottoms Stream Compositions | Species | wt. Frac | Species | wt. Frac | |
| | ACN | | ACN | trace | |
| | TOLUEN E | 0.00121 | TOLUEN E | 0.00619 | |
| | P- XYLENE | 0.45646 | P- XYLENE | 0.82978 | |
| | SILOXAN E | 0.07364 | SILOXAN E | 0.16403 | |

Table C-1: RADFRAC Column Design Summary

II. Reflux Drum Summary

| Reflux Drum Sizing | | | | | | | |
|-----------------------|--------------|--------------|--|--|--|--|--|
| Specification | Drum 1 | Drum 2 | | | | | |
| Diameter [m] | 0.320 | 0.486 | | | | | |
| Length[m] | 0.959 | 1.459 | | | | | |
| Volume [m^3] | 0.2408 | 0.557 | | | | | |
| Flow Rate [l/min] | 3.34 | 7.73 | | | | | |
| Holding Time [min] | 8 | 8 | | | | | |
| Reflux Ratio | 3.5 | 3.5 | | | | | |
| Liquid Space [%] | 50 | 50 | | | | | |
| Cost [\$] | \$4,251.00 | \$6,992.00 | | | | | |
| Material | Carbon Steel | Carbon Steel | | | | | |

Table C-2: Reflux Drums

III. Pump Summary

Table C-3: Pumps

| Pump Operation and Cost | | | | | | | | |
|-------------------------|--------------|--------------|-----------------|--|--|--|--|--|
| Specification | Pump 1 | Pump 2 | Vacuum | | | | | |
| Туре | Rotary | Rotary | Liquid Ring | | | | | |
| Power [kW] | 0.008 | 0.005 | 20.4 | | | | | |
| Flowrate [l/min] | 0.257 | 0.2004 | 0.306 | | | | | |
| Differential Head [m] | 11.10 | 11.64 | | | | | | |
| Pressure in [bar] | 0.10 | 0.1 | 1.00 | | | | | |
| Pressure out [bar] | 1.00 | 1.00 | 0.10 | | | | | |
| Cost [\$] | \$8,880 | \$8,880 | \$33,883 | | | | | |
| Material | Carbon Steel | Carbon Steel | Stainless Steel | | | | | |

IV. Flash Drum Summary

| Drum Separator Summary | | | | | | | |
|----------------------------|--------------|--------------|--|--|--|--|--|
| Specifications | Flash | Drum | | | | | |
| Temperature [°C] | | 138.00 | | | | | |
| Pressure [bar] | | 1.00 | | | | | |
| Diameter [m] | | 0.15 | | | | | |
| Height[m] | | 0.48 | | | | | |
| Volume [m^3] | | 0.01 | | | | | |
| Heat Duty [kW] | | 7.77 | | | | | |
| Туре | Vei | tical | | | | | |
| Material | 316SS | | | | | | |
| Cost | \$14,581 | | | | | | |
| | Component | Wt. Fraction | | | | | |
| | Acetonitrile | -trace- | | | | | |
| | Toluene | 0.007 | | | | | |
| Vapor Stream Compositions | p-Xylene | 0.861 | | | | | |
| | Water | 0 | | | | | |
| | Siloxane | 0.131 | | | | | |
| | Acetonitrile | -trace- | | | | | |
| | Toluene | 0.003 | | | | | |
| Liquid Stream Compositions | p-Xylene | 0.765 | | | | | |
| | Water | 0 | | | | | |
| | Siloxane | 0.245 | | | | | |

V. Storage Vessels

| Table C-5 | Storage | Tank | Sizing |
|-----------|---------|------|--------|
|-----------|---------|------|--------|

| Storage Vessel Sizing | | | | | | | | | |
|-----------------------|--------------------------|----------------|----------|-----------|----------|--|--|--|--|
| Storage Vessel | Volume [m ³] | Pressure [bar] | Material | Туре | Cost | | | | |
| Acetonitrile Tank | 18.80 | 1.0 | 316SS | Cone Roof | \$13,880 | | | | |
| Toluene Tank | 39.36 | 1.0 | 316SS | Cone Roof | \$19,630 | | | | |
| Feed B+C Tank | 29.42 | 1.0 | 316SS | Cone Roof | \$17,090 | | | | |
| Feed A Tank | 32.80 | 1.0 | 316SS | Cone Roof | \$18,000 | | | | |

| Waste Tank | 4.44 | 1.0 | 316SS | Cone Roof | \$7,456 |
|-------------------|-------|-----|-------|-----------|----------|
| P-Xylene | 3.28 | 1.0 | 316SS | Cone Roof | \$6,623 |
| Spill Containment | 59.04 | 1.0 | 316SS | Cone Roof | \$23,972 |

VI. Heat Exchanger Summary Part 1: E1 - E3,B

Table C-6: Summary of the first 5 heat exchangers in our process

| Heat Exchanger Summary | | | | | | | | | | | | | |
|-------------------------------------|----------|----------|----------|----------|----------|--|--|--|--|--|--|--|--|
| Block ID | E1 | E2-A | E2-B | E3-A | E3-B | | | | | | | | |
| Specification | | | | | | | | | | | | | |
| Heat duty [kW] | 1.459 | 10.88 | 0.7 | 10.684 | 8.76 | | | | | | | | |
| Actual exchanger area [sqm] | 0.046 | 0.207 | 0.013 | 0.575 | 0.204 | | | | | | | | |
| Minimum temperature approach [°C] | 10.0 | 10.0 | 10.0 | 10.0 | 10.0 | | | | | | | | |
| Туре | S&T | S&T | S&T | S&T | S&T | | | | | | | | |
| Flow Pattern | C-C | C-C | C-C | C-C | C-C | | | | | | | | |
| Hot Stream ID | ACN | XYL-RCY | XYL-RCY | TOL | TOL | | | | | | | | |
| Cooling Stream | MEK | CW | MEK | FEED-2A | MEK | | | | | | | | |
| Inlet hot stream temperature [°C] | 21.54 | 137.00 | 45.00 | 109.22 | 55.00 | | | | | | | | |
| Inlet hot stream pressure [bar] | 1.00 | 0.96 | 0.96 | 1.00 | 1.00 | | | | | | | | |
| Outlet hot stream temperature [°C] | 5.00 | 45.00 | 27.00 | 55.00 | 4.00 | | | | | | | | |
| Outlet hot stream pressure [bar] | 1.00 | 0.96 | 0.96 | 1.00 | 1.00 | | | | | | | | |
| Inlet cold stream temperature [°C] | -29.00 | 35.00 | -29.00 | 20.00 | -28.64 | | | | | | | | |
| Inlet cold stream pressure [bar] | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | | | | | | | | |
| Outlet cold stream temperature [°C] | -19.25 | 45.00 | -25.04 | 97.06 | -18.99 | | | | | | | | |
| Outlet cold stream pressure [bar] | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | | | | | | | | |
| Cost | \$10,793 | \$10,793 | \$10,793 | \$10,793 | \$10,793 | | | | | | | | |

VII: Heat Exchanger Summary: E4,A-D

| | Table (| C-7: | Summary | of the | final 4 | heat | exchance | jers |
|--|---------|------|---------|--------|---------|------|----------|------|
|--|---------|------|---------|--------|---------|------|----------|------|

| Heat Exchanger Summary | | | | | | | | | | | | |
|-----------------------------------|-------|-------|-------|-------|--|--|--|--|--|--|--|--|
| Block ID | E4-A | E4-B | E4-C | E4-D | | | | | | | | |
| Specification | | | | | | | | | | | | |
| Heat duty [kW] | .4857 | .304 | 8.76 | .3251 | | | | | | | | |
| Actual exchanger area [sqm] | 0.029 | 0.019 | 0.049 | 0.006 | | | | | | | | |
| Minimum temperature approach [°C] | 10.0 | 10.0 | 10.0 | 10.0 | | | | | | | | |
| Туре | S&T | S&T | S&T | S&T | | | | | | | | |

| Flow Pattern | C-C | C-C | C-C | C-C | |
|-------------------------------------|----------|----------|----------|----------|--|
| Hot Stream ID | WASTE | WASTE | WASTE | WASTE | |
| Cooling Stream | FEED-2A | BOT-1 | CW | MEK | |
| Inlet hot stream temperature [°C] | 63.18 | 137.00 | 116.76 | 45.00 | |
| Inlet hot stream pressure [bar] | 0.96 | 0.96 | 0.96 | 0.96 | |
| Outlet hot stream temperature [°C] | 45.00 | 116.76 | 63.18 | 27.00 | |
| Outlet hot stream pressure [bar] | 0.96 | 0.96 | 0.96 | 0.96 | |
| Inlet cold stream temperature [°C] | 35.00 | 97.06 | 52.91 | -29.00 | |
| Inlet cold stream pressure [bar] | 1.00 | 1.00 | 1.00 | 1.00 | |
| Outlet cold stream temperature [°C] | 45.00 | 100.00 | 62.91 | -28.64 | |
| Outlet cold stream pressure [bar] | 1.00 | 1.00 | 1.00 | 1.00 | |
| Cost | \$10,790 | \$10,790 | \$10,790 | \$10,790 | |

VIII: Mixer Summary

Table C-8: Mixer Sizing

| | Mixer 1 | | | | | | | | | | | | |
|-------------------|------------------|-------------------|-------------|--|--|--|--|--|--|--|--|--|--|
| Specification | Unstir | red, Motionle | ess Mixer | | | | | | | | | | |
| Hold Time [min] | | 5 | | | | | | | | | | | |
| Volume [m3] | | 0.0142 | | | | | | | | | | | |
| Diameter [m] | 0.0399 | | | | | | | | | | | | |
| | <u>Makeup In</u> | <u>Recycle In</u> | Recycle Out | | | | | | | | | | |
| Pressure [bar] | 1 | 0.98 | 1 | | | | | | | | | | |
| Temperature [°C] | 20 | 27 | 25.11 | | | | | | | | | | |
| Mass Flow [kg/hr] | 29.6 | 81.75 | 111.4 | | | | | | | | | | |
| Cost [\$] | | \$1,785.00 |) | | | | | | | | | | |
| Material | | Carbon Ste | el | | | | | | | | | | |

IX: Condenser and Reboiler Summary

Table C-9: Condenser and Reboilers

| Specifications | R1 | | R2 | | C1 | | C2 | | | |
|-------------------------|------------------|--------------------------|------------------|---------------------------|---------------------|----------|---------------------|------------------|--|--|
| Area [m ²] | | 3.8891 | | 5.323 | | 4.16 | 2.79 | | | |
| Duty [kW] | | 185.05 | | 169.8 | | -160.2 | -165 | | | |
| Туре | ke | ettle | k | ettle | kettle | ; | kettle | | | |
| | SEP-1 Bottoms | Low Pressure Steam | SEP-2 Bottoms | High Pressure Steam | SEP-1 Distillate | MEK | SEP-2 Distillate | Cooling Water | | |
| Pressure in [bar] | 0.10 | 1.72 | 1.00 | 10.33 | 0.10 | 1.00 | 1.00 | 1.00 | | |
| Pressure out [bar]] | 0.10 | 1.72 | 1.00 | 10.33 | 0.10 | 1.00 | 1.00 | 100 | | |
| Temperature in [°C] | 56 | 115.6 | 137.7 | 181.4 | 21.4 | 21.4 -29 | | 35 | | |
| Temperature Out [°C] | 51.6952 | 115.56 | 137.9 | 172.4 | 21.39 | 11.34 | 102 | 99.65 | | |
| Vapor Fraction In | 0 | 1 | 0 | 1 | 1 | 0 | 1 | 0 | | |
| Vapor Fraction Out | 0.774 | 1 | 0.783 | 1 | 0 | 0 | 0 | 0.074 | | |
| Flow rate [kg/hr] | 2160.5 | 1000 | 2339 | 13500 | 711.9 | 71 90 | 1632.6 | 14350 | | |

| | | Delivered Equip | oment Costs | | |
|-------------------|-----------|-----------------|-----------------|--------------|-----------|
| | Base Cost | Material Factor | Pressure Factor | Delivery Fee | True Cost |
| Mixer | \$1,732 | 1.0 | 1.0 | \$173 | \$1,905 |
| ACN Tower | \$8,886 | 4.0 | 1.7 | \$6,042 | \$66,467 |
| TOL Tower | \$13,283 | 4.0 | 1.7 | \$9,032 | \$99,357 |
| Reb -1 | \$10,793 | 1.0 | 1.0 | \$1,079 | \$11,872 |
| Cond - 1 | \$4,658 | 1.0 | 1.0 | \$466 | \$5,124 |
| Reb - 2 | \$10,793 | 1.0 | 1.0 | \$1,079 | \$11,872 |
| Cond -2 | \$5,551 | 1.0 | 1.0 | \$555 | \$6,106 |
| Pump 1 | \$2,222 | 1.4 | 1.0 | \$311 | \$3,422 |
| Pump 2 | \$2,222 | 1.0 | 1.0 | \$222 | \$2,444 |
| Vacuum Pump | \$16,212 | 1.9 | 1.0 | \$3,080 | \$33,883 |
| Reflux Drum 1 | \$3,581 | 1.0 | 1.0 | \$358 | \$3,939 |
| Reflux Drum 2 | \$4,971 | 1.0 | 1.0 | \$497 | \$5,468 |
| Flash Drum | \$14,581 | 1.0 | 1.0 | \$1,458 | \$16,039 |
| Heat Exchangers | \$97,137 | 1.0 | 1.0 | \$9,714 | \$106,851 |
| Acetonitrile Tank | \$13,880 | 1.0 | 1.0 | \$1,388 | \$15,268 |
| Toluene Tank | \$19,631 | 1.0 | 1.0 | \$1,963 | \$21,594 |
| Feed B+C Tank | \$17,093 | 1.0 | 1.0 | \$1,709 | \$18,802 |
| Feed A Tank | \$17,999 | 1.0 | 1.0 | \$1,800 | \$19,799 |
| Waste Tank | \$7,456 | 1.0 | 1.0 | \$746 | \$8,202 |
| P-Xylene | \$6,623 | 1.0 | 1.0 | \$662 | \$7,285 |
| Spill Containment | \$23,972 | 1.0 | 1.0 | \$2,397 | \$26,369 |
| Backup Pump 1 | \$2,222 | 1.4 | 1.0 | \$311 | \$3,422 |
| Backup Pump 2 | \$2,222 | 1.0 | 1.0 | \$222 | \$2,444 |
| Bkp Vc Pump | \$16,212 | 1.9 | 1.0 | \$3,080 | \$33,883 |
| | | | | Total Cost | \$531,819 |

Table C-10: Equipment Cost Summary

*Delivery Costs assumed to be ~10% of base cost

Appendix D: FMEA Summary

i. FMEA Definitions

The subsequent pages outline the results of our Failure Mode and Effects Analysis. The tables below define the rank ordered severity, occurrence, and detection parameters.

| | | SEVERITY |
|------|----------------------------|---|
| Rank | Effect rate | Criteria |
| 10 | Hazardous- without warning | Very high severity ranking when a potential failure mode affects personal safety, safe item operation and/or involves non-compliance with government regulation without warning |
| 9 | Hazardous- with warning | Very high severity ranking when a potential failure mode affects safe item operation and/or involves non-compliance with government regulation with warning |
| 8 | Very High | Item inoperable, with loss of primary function. |
| 7 | High | Item operable, but at reduced level of performance. Customer dissatisfied. |
| 6 | Moderate | Item operable, but Comfort/ Convenience item(s) inoperable. Customer experiences discomfort. |
| 5 | Low | Item operable, but Comfort/ convenience item(s) operable at reduced level of performance. Customer experiences some dissatisfaction. |
| 4 | Very low | Fit & finish/Squeak & Rattle item does not conform. Defect noticed by average customers. |
| 3 | Minor | Fit & finish/Squeak & Rattle item does not conform. Defect noticed by most customers. |
| 2 | Very minor | Fit & finish/Squeak & Rattle item does not conform. Defect noticed by discriminating customers. |
| 1 | None | No effect. |

OCCURRENCE

| Rank | CPK | Failure Rate | Criteria |
|------|------------------|----------------------------|-----------------------------|
| 10 | <u><</u> 0.33 | < 1 in 2 | Very High: |
| 9 | <u>></u> 0.33 | 1 in 3 | Failure almost inevitable |
| 8 | <u>></u> 0.51 | 1 in 8 | High: |
| 7 | <u>></u> 0.67 | 1 in 20 | Repeated failures |
| 6 | <u>></u> 0.83 | 1 in 80 | Moderate: |
| 5 | <u>></u> 1.00 | 1 in 400 | Occasional failures |
| 4 | <u>></u> 1.17 | 1 in 2000 | |
| 3 | <u>></u> 1.33 | 1 in 15 000 | Low: |
| 2 | <u>></u> 1.50 | 1 in 150 000 | Relatively few failures |
| 1 | <u>></u> 1.67 | <u><</u> 1 in 1 500 000 | Remote: Failure is unlikely |

| | | DETECTION |
|------|----------------------|---|
| Rank | Detection rate | Criteria |
| 10 | Absolute uncertainty | Design Control will not and/or cannot detect a potential cause/ mechanism and subsequent failure mode; or there is no Design Control. |
| 9 | Very remote | Very Remote chance the Design Control will detect a potential cause/mechanism and subsequent failure mode. |
| 8 | Remote | Remote chance the Design Control will detect a potential cause/ mechanism and subsequent failure mode. |
| 7 | Very low | Very Low chance the Design Control will detect a potential cause/ mechanism and subsequent failure mode. |
| 6 | Low | Low chance the Design Control will detect a potential cause/mechanism and subsequent failure mode. |
| 5 | Moderate | Moderate chance the Design Control will detect a potential cause/mechanism and subsequent failure mode. |
| 4 | Moderately high | Moderately High chance the Design Control will detect a potential cause/mechanism and subsequent failure mode. |
| 3 | High | High chance the Design Control will detect a potential cause/mechanism and subsequent failure mode. |
| 2 | Very high | Very High chance the Design Control will detect a potential cause/mechanism and subsequent failure mode. |
| 1 | Almost certain | Design Controls will almost certainly detect a potential cause/mechanism and subsequent failure mode. |

ii. FMEA Tables

Table D.1: FMEA of RADFRAC Column and Pump

| Subsy stem | FUNCTI ON | POTEN TIAL | POTEN TIAL | POTEN TIAL | DETEC TION | SE V | 0 CC | D ET | RP N | Recomm ended | Responsi bility | SE V | 0 CC | D ET | RP N |
|---------------|--------------|---------------|---------------|---------------|---------------|---------|---------|---------|---------|-----------------|--------------------|---------|---------|---------|---------|
| No. | | FAILUR | CAUSE | EFFEC | METHO | | | | | Action(s) | Completi | | | | |
| | | E | S | TS | D | | | | | | on date | | | | |
| | | MODE | | | | | | | | | | | | | |
| RADFr | Separat | Stage | Too | Separati | bottoms | 8 | 1 | 1 | 8 | | | | | | 0 |
| ac | or | Drying | much | on will | flow rate | | | | | | | | | | |
| Column | | up | heat/Lo | be off | sensor | | | | | | | | | | |
| | | | w liquid | specific | and | | | | | | | | | | |
| | | | flow | ation. | feed | | | | | | | | | | |
| | | | rate | Most | flow rate | | | | | | | | | | |
| | | | | material | sensor | | | | | | | | | | |
| | | | | in | | | | | | | | | | | |
| | | | | distillate | | | | | | | | | | | |
| | | Foamin | Vapor | Hinder | Distillate | 5 | 2 | 1 | 10 | | | | | | 0 |
| | | g | Flow | vapor | flow rate | | | | | | | | | | |
| | | | rate to | flow | sensor | | | | | | | | | | |
| | | | large | rate, | and | | | | | | | | | | |
| | | | | and will | feed | | | | | | | | | | |
| | | | | possibly | flow rate | | | | | | | | | | |
| | | | | lead to | sensor | | | | | | | | | | |
| | | | | flooding | | | | | | | | | | | |
| | | Stage | Too | Separati | Distillate | 8 | 1 | 1 | 8 | | | | | | 0 |
| | | Floodin | little | on is off | flow rate | | | | | | | | | | |
| | | g | heat/Lo | specific | sensor | | | | | | | | | | |
| | | _ | w vapor | ation. | and | | | | | | | | | | |
| | | | Flow | Most | feed | | | | | | | | | | |
| | | | rate | material | flow rate | | | | | | | | | | |
| | | | | in | sensor | | | | | | | | | | |
| | | | | bottoms | | | | | | | | | | | |

| Pump | Vacuum | Jam closed | Solid particul ate blocking pump | No flow/red uced flow out of pump. Incorrec t operatin g pressur e | Flow rate sensor at pump exit to detect decreas e in flow rate | 10 | 1 | 1 | 10 | | | 0 |
|------|--------|---------------|--|---|--|----|-----|---|----|--|--|---|
| | Compre | Motor | Mechan | Separati | Flow | 8 | 7.5 | 1 | 60 | | | 0 |
| | ssor | Fails | ical malfunc | on is off | rate | | | | | | | |
| | | running | tion | ation, | at pump | | | | | | | |
| | | 5 | | and | exit | | | | | | | |
| | | | | producti | | | | | | | | |
| | | | | on will | | | | | | | | |
| | | | | stopped | | | | | | | | |
| | | Electric | Equipm | Separati | Flow | 8 | 2 | 1 | 16 | | | 0 |
| | | al | ent | on is off | rate | | | | | | | |
| | | contacts | Malfunc | specific | sensor | | | | | | | |
| | | tail to | tion | ation | at pump | | | | | | | |
| | | start | | | exit | | | | | | | |

| Subsy | FUNC | POTEN | POTENT | POTENTI | DETEC | S | 0 | D | R | Recomm | Respons | S | 0 | D | R |
|-------|--------|---------|-----------|-----------|----------|----|---|----|----|-----------|----------|---|---|----|----|
| stem | TION | TIAL | IAL | AL | TION | Ε | С | ET | Ρ | ended | ibility | Е | С | ET | Ρ |
| No. | | FAILUR | CAUSES | EFFECTS | METHO | V | С | | Ν | Action(s) | Completi | V | С | | Ν |
| | | E | | | D | | | | | | on date | | | | |
| | | MODE | | | | | | | | | | | | | |
| Flash | Single | Floodin | Inlet | Reverse | flow | 8 | 1 | 1 | 8 | | | | | | 0 |
| Drum | stage | g | temperat | Flow | rate | | | | | | | | | | |
| | separa | - | ure too | | sensor | | | | | | | | | | |
| | tion | | low/pres | | on inlet | | | | | | | | | | |
| | | | sure to | | stream | | | | | | | | | | |
| | | | high, or | | | | | | | | | | | | |
| | | | flow rate | | | | | | | | | | | | |
| | | | is too | | | | | | | | | | | | |
| | | | large | | | | | | | | | | | | |
| | | drying | Inlet | No liquid | flow | 8 | 1 | 1 | 8 | | | | | | 0 |
| | | up | Tempera | flow. | rate | | | | | | | | | | |
| | | | ture too | Which | sensor | | | | | | | | | | |
| | | | high/pre | would | on | | | | | | | | | | |
| | | | ssure | result in | liquid | | | | | | | | | | |
| | | | too low, | incorrect | exit | | | | | | | | | | |
| | | | or flow | recycle | stream | | | | | | | | | | |
| | | | rate is | concentr | | | | | | | | | | | |
| | | | too low | ations | | | | | | | | | | | |
| Shell | Coolin | Outlet | incorrec | Material | Temper | 10 | 1 | 1 | 10 | yearly | | | | | 0 |
| and | g | temper | t flow | may be | ature | | | | | maintena | | | | | |
| Tube | | ature | rates/fou | above | sensor | | | | | nce to | | | | | |
| Heat | | too | ling | flash | on hot | | | | | reduce | | | | | |
| Excha | | high | | point | stream | | | | | risk of | | | | | |
| nger | | | | | exit | | | _ | | fouling | | | | | |
| | | Tube | Leak/Ru | Contamin | Temper | 8 | 8 | 3 | 19 | flow | | 8 | 8 | 1 | 64 |
| | | failure | pture | ation of | ature | | | | 2 | sensor | | | | | |
| | | | | streams | sensors | | | | | on inlet | | | | | |
| | | | | | on inlet | | | | | and exit | | | | | |
| | | | | | | | | | | stream | | | | | |

Table D.2: FMEA of Flash Drum, Shell and Tube Heat Exchanger, and Piping

| | | | | | and avit | | | | | | | |
|--------|--------|------|----------|------------|----------|----|---|---|----|--|--|--|
| | | | | | and exit | | | | | | | |
| | | | | | streams | | | | | | | |
| Piping | Piping | leak | wear | possible | Operato | 10 | 1 | 6 | 60 | | | |
| | Joint | | and tear | health | r | | | | | | | |
| | | | | effects | awaren | | | | | | | |
| | | | | and the | ess | | | | | | | |
| | | | | small | | | | | | | | |
| | | | | possibilit | | | | | | | | |
| | | | | y that a | | | | | | | | |
| | | | | material | | | | | | | | |
| | | | | will be | | | | | | | | |
| | | | | released | | | | | | | | |
| | | | | from a | | | | | | | | |
| | | | | stream | | | | | | | | |
| | | | | with low | | | | | | | | |
| | | | | pressure | | | | | | | | |
| | | | | and high | | | | | | | | |
| | | | | temperat | | | | | | | | |
| | | | | ure that | | | | | | | | |
| | | | | will be | | | | | | | | |
| | | | | well | | | | | | | | |
| | | | | above | | | | | | | | |
| | | | | the flash | | | | | | | | |
| | | | | point and | | | | | | | | |
| | | | | i | | | | | | | | |

Table D.3: FMEA for Mixer, Processing and Intermediate Units, Operator, and Control System/Process Automation

| Subsys | FUNCTI | POTEN | POTEN | POTEN | DETECTI | S | 0 | D | R | Recomm | Respons | S | 0 | D | R |
|---------|--------|-------|-------|-------|---------|---|---|---|---|-----------|----------|---|---|---|---|
| tem No. | ON | TIAL | TIAL | TIAL | ON | Ε | С | Ε | Ρ | ended | ibility | Е | С | Ε | Ρ |
| | | FAILU | CAUSE | EFFEC | METHOD | V | С | Т | Ν | Action(s) | Completi | V | С | Т | Ν |
| | | RE | S | TS | | | | | | | on date | | | | |
| | | MODE | | | | | | | | | | | | | |

| Mixer | Contain ment | Overflo w | Inlet flow rate too large, or exit flow rate is too low | could lead to spills, and potenti al health effects to anyone in proximi ty with the mixer | Liquid level sensor | 9 | 1 | 1 | 9 | Include a spill/over flow tank with a fail open switch | | | | 0 |
|---|--|---|---|--|---|----|----|---|---------|--|---|---|---|----|
| Proces sing and Interme diate Units | Power | Power failure for more than 20 minute s | Blacko ut, Electri cal issues, etc | Plant inopera ble | Operator awarenes s | 8 | 10 | 1 | 80 | | | | | 0 |
| Operat or | Unit Operatio n and Maintena nce | Proced ural Violati on | Human error | Serious injury | Operator awarenes s | 10 | 1 | 1 | 10 | | | | | 0 |
| Control System and Proces s Automa tion | Thermoc ouple | Equip ment malfun ction | wear and tear | Incorre ct input into controll loop, which could result in the | automate d comparis on with thermoco uples downstre am and comparis | 10 | 8 | 2 | 16 0 | include thermoc ouples inside vessels that are hazardou s as well | 8 | 6 | 2 | 96 |

| | | | system being off specific ation | on to literature values | | | | | at at the inlet/exit | | | |
|----------------------------|-----------------------|----------------|--|---|----|---|---|----|-------------------------|--|--|---|
| Generic Control Loop | Compu ter error | Power surge | System off spec possibl e safety hazards | Thermoc ouples at points of potential hazards | 10 | 6 | 1 | 60 | | | | 0 |

| Subsy | FUNCT | POTENTI | POTEN | POTEN | DETECT | S | 0 | D | R | Recomm | Respons | S | 0 | D | R |
|--------|---------|-----------|-----------|----------|-----------|---|----|---|----|-----------|----------|---|---|---|---|
| stem | ION | AL | TIAL | TIAL | ION | Ε | С | Е | Ρ | ended | ibility | Е | С | Ε | Ρ |
| No. | | FAILURE | CAUSE | EFFECT | METHO | V | С | Т | Ν | Action(s) | Completi | V | С | Т | Ν |
| | | MODE | S | S | D | | | | | | on date | | | | |
| Contro | Differe | Malfuncti | wear | Separati | Check | 8 | 10 | 1 | 80 | | | | | | 0 |
| 1 | ntial | oning | and tear | on will | during | | | | | | | | | | |
| Syste | Pressu | part | | be off | startup. | | | | | | | | | | |
| m and | re | _ | | specific | lf no | | | | | | | | | | |
| Proces | Sensor | | | ation | change | | | | | | | | | | |
| S | | | | | in | | | | | | | | | | |
| Autom | | | | | Pressur | | | | | | | | | | |
| ation | | | | | e there's | | | | | | | | | | |
| | | | | | а | | | | | | | | | | |
| | | | | | problem | | | | | | | | | | |
| | Differe | Malfuncti | Blocked | Overflo | Increme | 4 | 10 | 2 | 80 | | | | | | 0 |
| | ntial | oning. | entranc | w | ntally | | | | | | | | | | |
| | Pressu | Incorrect | e/exit of | | drain | | | | | | | | | | |
| | re | level | sensor. | | storage | | | | | | | | | | |
| | Transd | recorded | Electric | | tanks to | | | | | | | | | | |
| | ucer | | al | | determi | | | | | | | | | | |
| | (Level | | issues. | | ne flow | | | | | | | | | | |
| | Sensor | | Incorre | | rate, | | | | | | | | | | |
| |) | | ct | | pressur | | | | | | | | | | |
| | | | connect | | e, then | | | | | | | | | | |
| | | | ion etc | | ultimate | | | | | | | | | | |
| | | | | | ly | | | | | | | | | | |
| | | | | | Height | | | | | | | | | | |
| | | | | | of fluid. | | | | | | | | | | |
| | | | | | Could | | | | | | | | | | |
| | | | | | be | | | | | | | | | | |
| | | | | | Automat | | | | | | | | | | |
| | | | | | ed | | | | | | | | | | |

Table D.4: FMEA for Control Systems and Process Automation Continued

| Contro | fail | Comput | Separati | Flow | 8 | 6 | 1 | 48 | | | 0 |
|---------|-----------|----------|----------|----------|---|---|---|----|--|--|---|
| I Valve | open/clos | er/logic | on off | rate | | | | | | | |
| | е | controll | specific | sensor | | | | | | | |
| | | er | ation. | at inlet | | | | | | | |
| | | malfunc | Loss of | and exit | | | | | | | |
| | | tion. | material | of valve | | | | | | | |
| | | | | to | | | | | | | |
| | | | | ensure | | | | | | | |
| | | | | the | | | | | | | |
| | | | | valve | | | | | | | |
| | | | | position | | | | | | | |
| | | | | corresp | | | | | | | |
| | | | | onds to | | | | | | | |
| | | | | measur | | | | | | | |
| | | | | ed | | | | | | | |
| | | | | values | | | | | | | |

Appendix E: HAZOP Summary

i. Determination of risk hierarchy

| | | | | | |
|-------------------------|---|--|--|---|---|
| Qualitative Method | | Risk Matri | x Example |) | Quantitative Method |
| Frequency Categories | Death, Equipment or Facility Loss (Hazard Severity 1) | Severe Injury, Major Facility Damage (Hazard Severity 2) | Injury, Illness, Minor Equipment or Facility Damage (Hazard Severity 3) | Minor Injury or Minor Equipment Damage (Hazard Severity 4) | Probability of Incident per hour or per operation |
| A Frequent | Risk Level I | Risk Level I | Risk Level I | Risk Level III | Greater than 1E-3 /hr or /op |
| B Probable | Risk Level I | Risk Level I | Risk Level II | Risk Level III | Greater than 1E-4 or equal to 1E- 3/hr or /op |
| C Occasional | Risk Level I | Risk Level II | Risk Level II | Risk Level IV | Greater than 1E-5 or equal to 1E-4 /hr or /op |
| D Remote | Risk Level II | Risk Level II | Risk Level IV | Risk Level IV | Greater than 1E-6 or equal to 1E-5 /hr or /op |
| E Improbable | Risk Level IV | Risk Level IV | Risk Level IV | Risk Level IV | Less than or equal to 1E-6 /hr or /op |

Figure E-1: Risk Matrix Used in HAZOP Analysis

| | Potential Hazards, Conseq | uences, and Prevention Techniques | |
|--------------------------------|--------------------------------------|---|---|
| Potential Hazard | Consequence | Prevention Tactic | Action Taken |
| Components exposed to | Serious Injury or possibly death. | Implement a Control loop equipped | Include an intrinsic fire alarm system. |
| temperatures above flash | Possible damage to surrounding | with thermocouples at cooler exits | |
| temperature | equipment | and at the entrances to the mixer and | |
| | | storage tanks. | |
| Operator skin contact or | Health issues of worker and | Minimize open containers, and | Require personnel to wear light PPE |
| inhalation of hazardous | possible liability. | conduct routine equipment checks | inside the plant. Isolate the mixer and |
| components | | for leaks, ruptures, etc. | storage tanks to minimize contact, and |
| | | | post pertinent MSDS around |
| | | | equipment. |
| Low and high pressure steam | Can cause serious injury | Include caution signs and railing | Require PPE around plant |
| | | around equipment using steam. | |
| | | Practice good | |
| Operator in contact with MEK | Will cause injury if in contact with | In the design of the plant limit piping | Include MSDS, caution signs, and |
| | skin | exposure of MEK | conduct routine maintenance on pipes |
| | | | and storage containers that include |
| | | | MEK. |
| Toluene, ACN, and Xylene vapor | All three components have | Components are cooled to avoid | Emphasis on daily safety checks, and |
| release | environmental impacts and are | flash. This also decreases volatility | in leak prevention specifically |
| | volatile liquids at room | | |
| | temperature | | |

Table E-1: Potential Hazards

ii. Key Tables

| Nam | Guide | Parameter | Potential | Effect | Safeguard | | | | Actions/Comment |
|-------|---------|-----------|-----------|---------------------|--------------|-------------------|------------------|-------------|-----------------------|
| e | word | | Hazard | | | <u>Consequenc</u> | Frequency | <u>Risk</u> | <u>s</u> |
| | | | | | | <u>e</u> | | | |
| Feed- | Low | Flow | No | Products off | Flow sensor | 3 | 1 | IV | Don't need the flow |
| 1 | | | immediat | specification. | at entrance | | | | sensor, however it |
| | | | e hazard | Incorrect | to column | | | | will be useful for |
| | | | | temperatures and | | | | | detecting if the feed |
| | | | | pressures will | | | | | is off specification |
| | | | | result through the | | | | | |
| | | | | system due to | | | | | |
| | | | | Heat | | | | | |
| | | | | exchanger/pump | | | | | |
| | | | | sizing | | | | | |
| | High | Flow | none | Separation off | Differential | 3 | 1 | IV | |
| | | | | specification. High | pressure | | | | |
| | | | | distillate flow in | sensor at | | | | |
| | | | | first column. | entrance to | | | | |
| | | | | | column 1 | | | | |
| | | | | | with control | | | | |
| | | | | | valve | | | | |
| | No | Flow | none | No product being | Differential | 2 | 2 | IV | Not hazardous, but |
| | | | | made | pressure | | | | costly and will halt |
| | | | | | sensor at | | | | production for a |
| | | | | | entrance to | | | | variety of time, |
| | | | | | column 1 | | | | depending how |
| | | | | | | | | | automated the |
| | | | | | | | | | system is. |
| | Reverse | Flow | Could | Recycle process | Differential | 3 | 1 | IV | Would imply a |
| | | | result in | does not yield | pressure | | | | serious issue at the |
| | | | | product, and can | sensor to | | | | end of the siloxane |

| | | equipmen | disrupt the | determine | | | | polymerization |
|------|------------|------------|--------------------|---------------|-----|---|----|---------------------|
| | | t failure. | siloxane | the direction | | | | process, or a |
| | | | polymerization | of flow. | | | | buildup of pressure |
| | | | process | | | | | in the column over |
| | | | | | | | | time. |
| High | Temperatur | none | larger column1 | Thermocoupl | 1.5 | 2 | IV | One heat |
| | e | | feed temperature | e on feed | | | | exchangers would |
| | | | | | | | | not function |
| | | | | | | | | properly |
| Low | Temperatur | none | Separation will be | Thermocoupl | 1 | 2 | IV | Thermocouple not |
| | е | | off specification | e along the | | | | required |
| | | | | feed | | | | |
| High | Pressure | none | Separation will be | Pressure | 2 | 2 | IV | |
| | | | off specification | sensor in | | | | |
| | | | | feed | | | | |
| Low | Pressure | none | Better separation, | Pressure | 2 | 1 | IV | |
| | | | Higher operating | sensor in | | | | |
| | | | cost | feed | | | | |

| Name | Guide | Parameter | Potential | Effect | <u>Safeguard</u> | | | | Actions/Comme |
|--------------------------|-------|-----------|------------------|-----------|------------------|------------------|---------|-----|------------------|
| | Word | | <u>Hazard</u> | | | <u>Consequen</u> | Frequen | Ris | <u>nts</u> |
| | | | | | | ce | су | k | |
| Distkkkkkkkkkkkkkkkkkkkk | Low | Flow | none | More | Flow sensor | 1 | 2 | IV | |
| kkkk-1 | | | | cooling | at the exit | | | | |
| | | | | utility | of the reflux | | | | |
| | | | | used than | drum | | | | |
| | | | | needed | leading to | | | | |
| | | | | | the distillate | | | | |
| | High | Flow | Not | Residenc | Flow sensor | 3 | 1 | IV | At higher flow |
| | | | directly in | e time in | at exit of | | | | rates the hot |
| | | | this section | the | reflux drum | | | | stream is not |
| | | | of the | sequentia | to the | | | | cooled below |
| | | | stream, | l heat | distillate | | | | the flash point. |

| | | but does prove to be hazardous downstrea m | exchange r will be decrease d. | | | | | |
|-------------|----------|--|--|--|---|---|-----|--|
| No | Flow | None on this stream | No Acetonitri le product being made. Leaves the rest of the system in disarray | Flow rate sensor at the exit of the reflux drum to the distillate | 3 | 2 | 111 | Could indicate a malfunctioning reboiler which would result in only a liquid flow and no vapor flow to the condenser. |
| Revers e | Flow | none | No Acetonitri le recovery. Possible damage to equipmen t | Differential pressure sensor to determine the direction of flow. | 3 | 1 | IV | Could be caused by a malfunctioning compressor |
| Low | Pressure | If pressure is exceptiona Ily low it is possible for the to the ACN product | Lower capacity flow rate thus less heat transferre d | Differential pressure sensor at the exit of the reflux drum leading to the distillate | 4 | 1 | | |

| | | leaving the exchanger to have lower flash | | | | | | |
|------|-----------------|--|---|---|---|---|----|--|
| | | point | | | | | | |
| High | Pressure | none | Pressure exiting pump will be above 1 bar | Flow sensor at the exit of the reflux drum leading to the distillate | 1 | 2 | IV | |
| Low | Temperatu re | none | More cooling utility will be used than needed. | Thermocou ple at the exit of the reflux drum leading to the distillate | 1 | 2 | IV | Not unsafe, but is operating less efficiently. |

| Name | Guide | <u>Parameter</u> | Potential | Effect | <u>Safeguard</u> | | | | Actions/Comments |
|------|-------------|------------------|--------------|----------------|------------------|--------------------|------------------|-------------|------------------|
| | <u>Word</u> | | Hazard | | | <u>Consequence</u> | <u>Frequency</u> | <u>Risk</u> | |
| ACN | High | Flow | Serious | Exit into | Flow sensor | 4 | 1 | Ш | Emphasize |
| PROD | | | injury/death | container will | and | | | | workplace safety |
| | | | could result | be above flash | temperature | | | | precautions |
| | | | | point | sensor at the | | | | |
| | | | | | entrance and | | | | |
| | | | | | exit of the | | | | |
| | | | | | heat | | | | |
| | | | | | exchanger. Fail | | | | |
| | | | | | close valve will | | | | |
| | | | | | be needed. | | | | |

| Low | Flow | none | More utility will be used than needed | Flow sensor at inlet of heat exchanger | 2 | 1 | IV | |
|------|-------------|---|--|---|---|---|-----|--|
| No | Flow | none | No ACN is being produced | Flow sensor anywhere after the compressor pump. | 3 | 1 | IV | No revenue is made from the ACN product |
| High | Temperature | Serious injury/death to any personnel. Possible damage to equipment and facility | ACN is above flash point | Use a control loop that utilizes a Thermocouple on the stream leaving the heat exchanger and a fail close valve before the exit | 4 | 1 | 111 | |
| Low | Temperature | none | More cooling utility used than needed. | Thermocouple exiting the exchanger | 2 | 1 | IV | A lower temperature indicates less material used. This implies the bottoms of column 1 entering column 2 will have ACN that will make the toluene feed impure and non- profitable |
| High | Pressure | Increased chance to | Indicates a block or valve | Include a pressure | 3 | 1 | IV | Schedule routine maintenance to |

| | | leak or | malfunction | sensor after | | | | check for leaks and |
|-----|----------|------------|-----------------|-----------------|---|---|----|---------------------|
| | | rupture. | that is causing | the heat | | | | ruptures |
| | | Possible | a pressure | exchanger, | | | | |
| | | personnel | buildup. The | and | | | | |
| | | contact to | pressure sensor | implement a | | | | |
| | | ACN | earlier on in | control loop to | | | | |
| | | | the stream | sound an | | | | |
| | | | could also be | alarm at | | | | |
| | | | malfunctioning. | different | | | | |
| | | | | safety | | | | |
| | | | | thresholds | | | | |
| Low | Pressure | none | Malfunctioning | Include | 1 | 2 | IV | |
| | | | compressor | pressure | | | | |
| | | | pump | sensor as well | | | | |
| | | | | as a flow | | | | |
| | | | | meter before | | | | |
| | | | | and after the | | | | |
| | | | | compressor. | | | | |
| | | | | Compare inlet | | | | |
| | | | | and outlet | | | | |
| | | | | values to | | | | |
| | | | | determine | | | | |
| | | | | pump power. | | | | |
| | | | | | | | | |

| <u>Name</u> | <u>Guide</u> | <u>Parameter</u> | Potential | <u>Effect</u> | <u>Safeguard</u> | | | | Actions/Comments |
|-------------|--------------|------------------|---------------|-----------------|------------------|--------------------|------------------|-------------|----------------------|
| | <u>Word</u> | | <u>Hazard</u> | | | <u>Consequence</u> | <u>Frequency</u> | <u>Risk</u> | |
| H- | High | Flow | none | Not enough | Flow senso | r 4 | 2 | П | Could be a result of |
| WASTE2 | | | | cooling utility | before the | | | | flash drum |
| | | | | to meet | entrance to | | | | malfunction, or an |
| | | | | required | the next hea | it | | | issue earlier on in |
| | | | | design | exchanger | | | | the process. Halt |
| | | | | specifications | | | | | process if flow rate |
| | | | | | | | | | is too high |
| | No | Flow | None | Siloxane will | Control loc | op 3 | 1 | IV | |
| | | | | appear in the | equipped w | ith | | | |
| | | | | recycle | two differen | tial | | | |
| | | | | stream, and | pressure | | | | |
| | | | | the entire | transmitter | rs. | | | |
| | | | | process will no | One will b | e | | | |
| | | | | longer | place in th | e | | | |
| | | | | function up to | waste strea | m | | | |
| | | | | specifications | directly leav | ing | | | |
| | | | | as well as | the flash dru | ım. | | | |
| | | | | damage to | The other w | vill | | | |
| | | | | equipment. | be in the H | 1- | | | |
| | | | | | WASTE2 | | | | |
| | | | | | stream. | | | | |
| | High | Temperature | none on | Subsequent | Thermocou | ple 4 | 1 | IV | If flow rate is |
| | | | this | heat | and flow ra | te | | | within set |
| | | | stream | exchangers are | e sensor | | | | tolerance it could |
| | | | | not designed | | | | | indicate a |
| | | | | for this | | | | | malfunction in the |
| | | | | temperature | | | | | previous heat |
| | | | | which will | | | | | exchanger. Or |
| | | | | result in highe | r | | | | another error |
| | | | | temperatures | | | | | earlier in the |
| | | | | further down | | | | | process (Most |
| | | | | the stream | | | | | |

| | | | | Likely condenser |
|--|--|--|--|------------------|
| | | | | malfunction). |

| Name | <u>Guide</u> | Parameter | Potential | Effect | Safeguard | | | | Actions/Comments |
|------|--------------|-------------|--------------|------------------|------------------|--------------------|------------------|-------------|-----------------------|
| | Word | | Hazard | | | <u>Consequence</u> | Frequency | <u>Risk</u> | |
| MEK- | Low | Flow | Some Hot | Not enough | Implement a | 3 | 1 | IV | Ensure the |
| IN | | | streams | Cooling utility. | Control loop | | | | safeguard is |
| | | | that are | Halt process | that utilizes a | | | | installed, else there |
| | | | above their | until flow rate | fail open valve | | | | will be an increase |
| | | | flash points | is resolved. | on MEK | | | | in risk and possible |
| | | | will be open | | stream inlet to | | | | liabilities |
| | | | to the | | the heat | | | | |
| | | | atmosphere | | exchanger, | | | | |
| | | | | | and a fail close | | | | |
| | | | | | valve on the | | | | |
| | | | | | hot stream | | | | |
| | | | | | inlet to | | | | |
| | | | | | exchanger. | | | | |
| | Reverse | Flow | Some Hot | Will violate the | Implement a | 4 | 1 | III | Unlikely, but if it |
| | | | streams | countercurrent | differential | | | | occurs. The system |
| | | | that are | design of the | pressure | | | | will require |
| | | | above their | heat | transducer to | | | | shutdown until |
| | | | flash points | exchanger and | determine the | | | | safe operating |
| | | | will be open | decrease the | magnitude | | | | conditions can be |
| | | | to the | amount of | and direction | | | | met again |
| | | | atmosphere | cooling utility. | of flow | | | | |
| | High | Flow | None | Using more | Flow sensor at | 1 | 2 | IV | |
| | | | | cooling utility | inlet to | | | | |
| | | | | than needed | exchanger | | | | |
| | High | Temperature | Some Hot | Lowers the log | Thermocouple | 4 | 1 | | Not likely, but if |
| | | | streams | mean | before the | | | | the thermocouple |
| | | | that are | temperature | inlet to the | | | | read a value higher |
| | | | above their | difference | heat | | | | than the accepted |
| | | | flash points | which will | exchanger | | | | value shutdown |
| | | | will be open | decrease heat | | | | | operation until safe |
| | | | to the | transfer | | | | | operating |
| | | | atmosphere | | | | | | conditions are met. |

| <u>Name</u> | <u>Guide</u> | <u>Parameter</u> | Potential | Effect | <u>Safeguard</u> | | | | Actions/Comments |
|-------------|--------------|------------------|------------------|-----------------|------------------|------------------|----------|-------------|--------------------------|
| | <u>Word</u> | | <u>Hazard</u> | | | <u>Consequen</u> | Frequenc | <u>Risk</u> | |
| | | | | | | <u>ce</u> | У | | |
| CW- | Low | Flow | Hot | Not enough | PID control | 4 | 1 | Ш | Emphasize importance in |
| IN | | | stream | cooling | loop | | | | daily safety checklist |
| | | | doesn't | utility will be | connected | | | | |
| | | | get cooled | supplied | to a | | | | |
| | | | past the | resulting in a | differential | | | | |
| | | | flash | higher hot | pressure | | | | |
| | | | point. | stream | transducer | | | | |
| | | | | outlet | and a | | | | |
| | | | | temperature | control valve | | | | |
| | | | | than desired | | | | | |
| | No | Flow | Will most | No cooling | PID control | 4 | 2 | Ш | Failure most likely |
| | | | certainly | utility. | loop | | | | resulting from a |
| | | | result in | | connected | | | | malfunctioning valve, or |
| | | | errors | | to a | | | | more severely an issue |
| | | | further in | | differential | | | | with the house water |
| | | | the system | | pressure | | | | system |
| | | | | | transducer | | | | |
| | | | | | and a | | | | |
| | | | | | control valve | | | | |
| | Reverse | Flow | Will result | Cooling duty | PID control | 4 | 1 | Ш | Could have resulted from |
| | | | in | (if any) will | loop | | | | years of siloxane |
| | | | hazardous | be | connected | | | | particulate buildup |
| | | | situations | insufficient | to a | | | | |
| | | | further in | | differential | | | | |
| | | | the system | | pressure | | | | |
| | | | | | transducer | | | | |
| | | | | | and a | | | | |
| | | | | | control valve | | | | |
| | High | Temperature | Will result | Cooling duty | Thermocoup | 4 | 1 | III | |
| | | | in | will be will | le, control | | | | |

| | hazardous | be | loop, and | | |
|--|------------|--------------|-----------|--|--|
| | situations | insufficient | alarm | | |
| | further in | | | | |
| | the | | | | |
| | system, | | | | |
| | but this | | | | |
| | stream is | | | | |
| | not | | | | |
| | directly | | | | |
| | hazardous | | | | |
| Name | <u>Guide</u> | Parameter | Potential | Effect | Safeguard | | | | Actions/Comments |
|--------|--------------|------------------|------------------|-------------------|------------------|--------------------|------------------|-------------|------------------|
| | <u>Word</u> | | <u>Hazard</u> | | | <u>Consequence</u> | <u>Frequency</u> | <u>Risk</u> | |
| High P | low | flow | No | Column 2 | Flow rate | 4 | 1 | Ш | |
| Steam | | | immediate | reboiler does | sensor in | | | | |
| | | | hazard, but | not vaporize | the inlet to | | | | |
| | | | will result in | enough of the | the reboiler | | | | |
| | | | off spec | liquid to stay at | in column 2 | | | | |
| | | | recycle and | set specification | | | | | |
| | | | waste that | leading to | | | | | |
| | | | will be above | flooding | | | | | |
| | | | the flash | | | | | | |
| | | | point | | | | | | |
| | High | flow | Toluene | Most material | Flow rate | 4 | 1 | 1111 | |
| | | | product | will end in the | sensors on | | | | |
| | | | stream will | distillate. | steam | | | | |
| | | | be above its | Increasing the | entering | | | | |
| | | | flash point | capacity flow of | the reboiler | | | | |
| | | | | the toluene | in column 2 | | | | |
| | | | | product stream | | | | | |
| | | | | thus the change | | | | | |
| | | | | in temperature | | | | | |
| | | | | is less than | | | | | |
| | | | | specified in the | | | | | |
| | | | | design. | | | | | |

| Name | <u>Guide</u> | <u>Parameter</u> | <u>Potential</u> | Effect | <u>Safeguard</u> | | | | Actions/Comments |
|----------|--------------|------------------|------------------|-----------------|------------------|-------------|------------------|-------------|-----------------------|
| | Word | | <u>Hazard</u> | | | Consequence | <u>Frequency</u> | <u>Risk</u> | |
| RADFRAC1 | High | Flow | none | Liquid level in | High Flow | 3 | 1 | IV | |
| | | | | column will | alarm | | | | |
| | | | | rise gradually | | | | | |
| | | | | until the | | | | | |
| | | | | column | | | | | |
| | | | | ceases to | | | | | |
| | | | | work | | | | | |
| | Low/zero | Flow | If flow rate is | Temperature | Flow | 3 | 1 | IV | If precipitation of |
| | | | too small | rise in | sensors at | | | | siloxane occurs. |
| | | | precipitation | column | both | | | | Equipment will have |
| | | | of siloxane | causing most | feeds | | | | to be cleaned at the |
| | | | may occur. | components | | | | | least which costs |
| | | | | to go to the | | | | | money. Proving it is |
| | | | | distillate | | | | | not economically |
| | | | | | | | | | viable to run the |
| | | | | | | | | | column at flow |
| | | | | | | | | | rates less than the |
| | | | | | | | | | design specification |
| | High | Level | Possible | Flooding, and | High level | 2 | 1 | IV | Best to shut down |
| | | | hazards later | reboiler stops | alarm, | | | | the process, drain |
| | | | in column | functioning | and | | | | the column, and |
| | | | due to the | | shutdown | | | | restart the process |
| | | | large liquid | | | | | | after determining |
| | | | flow rate | | | | | | the source of error. |
| | Low | Level | Column can | Possible | Low level | 3 | 1 | IV | Will usually be |
| | | | get too hot | chance | alarm | | | | detected by level |
| | | | | stages will | | | | | sensors, but can |
| | | | | dry out | | | | | also found from |
| | | | | | | | | | differential pressure |
| | | | | | | | | | transmitters and |
| | | | | | | | | | thermocouple |
| | | | | | | | | | readings of the |

| | | | | | | | | bottoms and distillate |
|------|----------|---|---|---|---|---|----|--|
| High | Pressure | Column become more susceptible to leaks | Separation of ACN will not reach required design specification | Pressure sensor in column | 3 | 1 | IV | Follow city regulations on environmental waste disposal |
| Low | Pressure | | Vacuum is using more power than needed | Pressure sensor at inlet and exit of vacuum pump | 2 | 1 | IV | Costly to run at pressures lower than .1 bar |

| Name | <u>Guide</u> | Parameter | Potential | Effect | Safeguard | | | | Actions/Comments |
|-----------|--------------|---------------|---------------|---------------|------------------|--------------------|------------------|-------------|----------------------|
| | <u>Word</u> | | Hazard | | | <u>Consequence</u> | <u>Frequency</u> | <u>Risk</u> | |
| Heat | High | Inlet cooling | The stream | There is a | Thermocouple | 3 | 1 | IV | |
| Exchanger | | stream | itself is not | decrease in | at the Inlet of | | | | |
| | | temperature | hazardous, | the rate of | the cooling | | | | |
| | | | but the | cooling due | stream | | | | |
| | | | insufficient | to the lower | | | | | |
| | | | cooling of | value of the | | | | | |
| | | | easily | log mean | | | | | |
| | | | ignitable | temperature | | | | | |
| | | | materials can | difference | | | | | |
| | | | be. | | | | | | |
| | High | Exit hot | Product is | The hot exit | Thermocouples | 4 | 1 | III | Use/write a |
| | | stream | above its | stream | and Flow | | | | program help in the |
| | | temperature | flash | stream is not | sensors placed | | | | automation |
| | | | temperature, | cooled below | at the hot | | | | process. Have it |
| | | | and exposed | its flash | stream | | | | cross check |
| | | | to open air | temperature, | entrance and | | | | measured values |
| | | | | and exposed | exit as well as | | | | and design specific |
| | | | | to open air | the inlet | | | | values, and if it is |
| | | | | | cooling stream. | | | | out of the accepted |
| | | | | | Also include a | | | | tolerance value |
| | | | | | fail close valve | | | | actuate the fail |
| | | | | | on the hot | | | | close valve and |
| | | | | | stream exit | | | | sound an alarm. |

| Equipment | Ruptured | Outlet hot | The cooling | Include | 4 | 1 | | If cross |
|-------------|----------|-------------|--------------|--------------|---|---|--|-------------------|
| Malfunction | tube | stream | stream and | flow rate | | | | contamination is |
| | | could be | heating | sensors at | | | | allowed to |
| | | above flash | stream cross | all inlets | | | | continue or goes |
| | | and open to | contaminate | and exits of | | | | unnoticed; entire |
| | | atmosphere | | exchanger | | | | process streams |
| | | | | to | | | | |

| | | determine | | |
|--|--|-------------|--|--|
| | | if there is | | |
| | | crossover | | |

Appendix F: Utility Summary

The subsequent tables are a summary of the refrigerants used, and their annual cost assuming a working year of 8000 hours. Each calculation is based on the utility price displayed below in table G-1.

| Utility Cost | | | | | | | |
|----------------------|-------------|-------|--|--|--|--|--|
| Cooling Water | 0.000402 | \$/kg | | | | | |
| MEK | 0.000019706 | \$/kJ | | | | | |
| Steam (P,T) | | | | | | | |
| 172 kPa, 115 C | 0.0211 | \$/kg | | | | | |
| 1034 kPa, 181.4 C | 0.0244 | \$/kg | | | | | |
| Electricity | 0.00002 | \$/kJ | | | | | |

Table G-1: Cost of Cooling, Heating, and Electrical Utilities

i. Electric Usage:

| Electricity Usage | | | | | | | | |
|-------------------|---------------------|----------|-------------|--|--|--|--|--|
| | Electricity [kW] | \$/kW | Annual Cost | | | | | |
| Pump -1 | 3.60E-02 | 7.19E-07 | \$202 | | | | | |
| Pump -2 | 3.39E-02 | 6.79E-07 | \$19 | | | | | |
| Vacuum Pump | 3.00E+01 | 4.60E-04 | \$13,261 | | | | | |
| | | Total | \$13,301 | | | | | |

Table G-2: Cost to Run Electrical Equipment

ii. Cooling Water Usage

| Table | G-3: | Cooling | Water |
|-------|------|---------|-------|
|-------|------|---------|-------|

| Cooling Water Usage | | | | | | | |
|---------------------|------------------------------------|-------------|--|--|--|--|--|
| Unit | Unit Mass Flow [kg/hr] Annual Cost | | | | | | |
| E2-A | 940.1 | \$30,244.87 | | | | | |

| | Total | | \$95,497.51 |
|-------------|-------|------|-------------|
| Condenser 2 | | 2000 | \$64,320.00 |
| E4-C | | 29.2 | \$932.64 |
| E4_C | | 20.2 | ¢032 |

iii. MEK Usage

| MEK Usages | | | | | | |
|------------|----------------|--------------------------------------|----------------|-----------|--|--|
| Unit | kW Required | Annual Energy Consumption (kJ) | Cost of MEK | True Cost | | |
| E1 | 1.4 | 40320000 | \$794 | \$3,971 | | |
| E2-B | 0.7 | 20160000 | \$397. | \$1,588 | | |
| E3-B | 8.76 | 252288000 | \$4,970 | \$19,880 | | |
| ED-4 | 0.325 | 9360000 | \$184 | \$737 | | |
| Cond 1 | 160 | 4608000000 | \$90,777 | \$363,110 | | |
| | | | Total | \$389,288 | | |

iv. Steam Usage

Table G-5: Steam Consumption

| Steam Usage | | | | | |
|-------------|--------------------|--------------|-------------|--|--|
| Unit | Steam Flow [kg/hr] | Cost [\$/kg] | Annual Cost | | |
| Reboiler 1 | 300 | 0.0211 | \$50,640 | | |
| Reboiler 2 | 300 | 0.0244 | \$58,560 | | |
| Flash Drum | 12.35 | 0.0244 | \$2,411 | | |
| | | Total Cost | \$111,611 | | |

Appendix G: Inherently Safer Design Checklist

- I. Minimize
 - A. Inventory Reduction (Calibri body)
 - 1. Can hazardous raw materials inventory be reduced? <u>No. All profit comes from the recycling of hazardous materials back into the process.</u>
 - 2. Can in-process storage and inventory be reduced? <u>No. Already taken into consideration</u>
 - 3. Can finished product inventory be reduced? <u>No.</u>
 - B. Process Considerations
 - 1. Can the use of alternate equipment with reduced hazardous material inventory requirement be done? Such as:
 - a) Continuous in-line mixers in place of mixing vessels Yes. It would be costly, and would severely alter the process
 - b) Compact heat exchangers (higher heat transfer area per unit volume) in place of shell-and tube

No. The flow rate is too high for a feasible compact exchanger.

c) Combine unit operations (such as reactive distillation in place of separate reactor with multi-column fractionation train; installing internal reboilers or heat exchangers) to reduce overall system volume

No. No stream would provide adequate heat duty to replace a reboiler.

- Has piping been designed for reducing the piping diameters?
 <u>Will be considered in later design. The only exception being the gravity</u> <u>driven cooling streams.</u>
- Can pipeline inventory be reduced by using the hazardous material as a gas rather than a liquid (e.g., chlorine)?
 <u>No.</u>
- 4. Can process conditions be changed to reduce production of hazardous waste or by-products?

No. The process is currently operating at the minimum allowable concentration of p-xylene in the waste.

II. Substitute

- A. Is it possible to completely eliminate hazardous raw materials, process intermediates, or by-products by using an alternative process or chemistry? <u>No. The process is chemical specific.</u>
- B. Is it possible to completely eliminate in-process solvents and flammable heat transfer media by changing chemistry or processing conditions?
 No. The addition of p-xylene is needed to separate toluene from acetonitrile.
- C. Is it possible to substitute less hazardous raw materials? No.
- III. Moderate
 - A. Is it possible to limit the supply pressure of raw materials to less than the maximum allowable working pressure of the vessels they are delivered to? No. All pressures are set and decreasing pressure would just tax the system further.
 - B. Is it possible to make reaction conditions (temperature, pressure) less severe by using a catalyst, or a better catalyst?
 <u>No. Already taken into consideration with the addition of p-xylene to increase the ease of separation.</u>
 - C. Can the process be operated at less severe conditions? No. All temperatures and pressures are set to meet separation specifications.
 - D. Is it possible to dilute hazardous raw materials to reduce the hazard potential? <u>No.</u>
 - E. Is it possible to design operating conditions such that materials that become unstable at elevated temperatures or freeze at low temperatures heating and cooling medium will not be operating in those ranges?
 No. Sharp Separation, in this case, can only be achieved at elevated temperatures.
 - F. Can process conditions be changed to avoid handling flammable liquids above their flash points?

Yes. The changes have already been implemented.

- G. Is equipment designed to totally contain the materials that might be present inside at ambient temperature or the maximum attainable process temperature (i.e., higher maximum allowable working temperature to accommodate loss of cooling, simplify reliance of external systems such as refrigeration systems to control temperature such that vapor pressure is less than equipment design pressure)? <u>Yes.</u>
- H. For processes handling flammable materials, is it possible to design the layout to minimize the number and size of confined areas and to limit the potential for serious overpressure in the event of a loss of containment and subsequent ignition?

Yes. Will be a major consideration in plant design.

- I. Can process units be located to eliminate or minimize adverse effects from adjacent hazardous installations? <u>Yes. Install splash guards on drains to reduce contamination. Isolate the exits of</u> the high volatility liquids in one section to reduce risk to the rest of plant.
- J. Can process units be designed to limit the magnitude of process deviations: Yes. Already taken into consideration.

- K. Can hazardous material liquid spill be prevented from entering drainage system/sewer? Yes. Install splash guards over waste water gutters. All flammable stream exits/containment should be at a lower height than the rest of the process to reduce contamination.
- L. For flammable materials, can spills be directed away from the storage vessel to reduce the risk of a boiling liquid expanding vapor explosion (BLEVE) in the event of a fire?

Yes. Design the plant on a slight incline, and implement different levels of drains.

M. Passive safety design is preferred. Can passive design be implemented? For example, to prevent or reduce fire damage, an active method is automatic water spray actuated by flame or heat detector; a procedural method by having an operator turn on the water spray, or passive method by using fire insulation.

Yes. Can see implications an implementations in the P&ID diagram.

- IV. Simplify
 - A. Can equipment be designed such that it is difficult or impossible to create a potential hazardous situation due to an operating or maintenance error? Such as:
 - 1. Easy operation of valves designed to prevent inadvertent errors Yes. Most of the valve actuators will be run autonomously.
 - 2. Simplified control displays Yes. Will be a consideration when deciding on the control software to use.
 - 3. Operate at lower pressure to limit release <u>No.</u>
 - 4. Operate at lower temperature to prevent run away reactions or material failure

Not possible. All temperatures are set to meet design specifications.

- 5. Use passive rather than active controls Yes. Currently implementing both.
- 6. Use buried or shielded tanks Yes. Already taken into consideration.
- Use fail-safe controls if utilities are lost Yes. Fail open valves on cooling utilities, and fail close valves on streams entering the atmosphere containing liquids above their flash point.
- 8. Limit the complexity and degree of instrumentation redundancy Yes. There are some instrumentation redundancies, but these redundancies help locate errors quickly.
- 9. Use refrigerated storage vs. pressurized storage <u>Yes. Already taken into consideration.</u>
- 10. Minimize connections, paths and number of flanges in hazardous processes

Yes. Needs to be considered in further design.

11. Use fewer bends in piping Yes. Should be considered later in the design process.

- 12. Use expansion loops in piping rather than bellows Yes. Space is not an issue, so an expansion loop should be used.
- 13. Design into the process, equipment isolation mechanism for maintenance Yes. Already taken into consideration, but should still be investigated further as the design evolves.
- 14. Limit manual operations such as filter cleaning, manual sampling, hose handling for loading/unloading operations, etc. Yes. The process is automated as much as possible.
- 15. Design vessels for full vacuum eliminating risk of vessel collapse <u>Yes. Already taken into consideration, i.e. of the vacuum pump.</u>
- 16. Design both shell and tube side of heat exchangers to contain the maximum attainable pressure, eliminating the need for pressure relief Yes.
- 17. Can the equipment be designed to make incorrect assembly impossible? Use equipment that clearly identifies status
- B. Can passive leak-limiting technology be used to limit potential loss of containment? Some examples include the following:

We are not at this point in the design process. A leak of a stream containing a liquid above its flash point is still a serious safety concern, thus this section should be taken into further consideration at a later point.

- 1. Blowout resistant gaskets <u>Yes.</u>
- 2. Increasing wall strength <u>Yes.</u>
- 3. Using fewer seams and joints <u>Yes.</u>
- 4. Providing extra corrosion/erosion allowance No. None of the materials used are considered very corrosive.
- 5. Reducing vibration Yes. Should at least be considered
- 6. Minimizing the use of open-ended, quick-opening valves <u>Yes.</u>
- Eliminating open-ended, quick-opening valves in hazardous service <u>Yes.</u>
- 8. Improving valve seating reliability <u>Yes.</u>
- 9. Eliminating unnecessary expansion joints, hoses, and rupture disks <u>Yes.</u>
- 10. Eliminating unnecessary sight glasses/glass rotameters <u>Yes.</u>
- V. Transport of Hazardous Materials
 - A. Can the plant be located to minimize need for transportation of hazardous materials?

Yes. The plant is supplying most of the hazardous materials back to itself. The waste is the only material leaving the plant and is composed of mostly p-xylene which can flash at temperatures slightly above room temperatures. Plant location should be considered, but is not mandatory.

- B. Can materials be transported:
 - 1. In a less hazardous form Yes. The waste should be kept refrigerated
 - 2. In a safer transport method. Yes. Consider using trains instead of semi-trucks to transport waste
 - 3. In a safer route Should be considered depending on location

i. Economics

a. Delivered Equipment Cost

This method is used to cost all equipment using values given by EconExpert $DEC = [Base Cost] \cdot [M_{factor}] \cdot [P_{factor}] \cdot [Delivery Fee]$ Where: $DEC \equiv Delievered \ Equipment \ Cost$ $M_{factor} \equiv Material \ Factor \ [From \ EconExpert]$ $P_{factor} \equiv Pressure \ Feactor \ [From \ EconExpert]$ $Delivery \ Fee = 1.1 \ (10\% \ Fee)$ $DEC_{ACNTower} = [\$8,886] * (1.7 * 4.0) * 1.1 = \$66,467$

b. Fixed Capital Investment

$$FCI = Total Plant Cost = Total Direct Cost (TDC) + Total Indirect Cost (TIC) + ContractingWhere:
$$TDC \equiv 244\% \text{ of } DEC_{total}$$
$$TIC \equiv 80\% \text{ of } DEC_{total}$$
$$Contracting \equiv 63\% \text{ of } DEC_{total}$$
Percentages Given by Peters and Timmerhaus (1981)
$$FCI = (2.44 + 0.8 + 0.63) \cdot [\$531,819]$$
$$FCI = \$2,058,140$$$$

c. Total Product Cost

 $Total \ Product \ Cost = Manufacturing \ Cost + General \ Expenses \\ Where: \\ Mfg \ Cost = 24.2\% \ of \ FCI + 15\% of \ Labor \ Cost + 55\% of \ (Labor + Superv. + Maint.) \\ General \ Expenses \equiv 15\% \ of \ Mfg \ Cost + 15\% \ of \ (Labor + Superv. + Maint.) \\ Total \ Product \ Cost = \$1,144,360 + \$320,100 = \$1,464,000 \\ \end{cases}$

d. Working Capital Investment (WCI)

 $WCI = 86\% of DEC_{total}$ WCI = \$457,360 [Recovered at year 20]

e. Total Capital Investment (TCI)

TCI = WCI + FCITCI = \$457,360 + \$2,060,000TCI = \$2,520,000

f. Labor Costs

Labor Cost =
$$\frac{1}{4} \cdot \left(\frac{8000 \text{ hr}}{\text{year}}\right) \cdot [\# \text{ Workers}] \cdot \left[\frac{\$}{\text{hr} \cdot \text{Worker}}\right] * [\text{Benefits}]$$

Where
Workers = 8
 $\frac{\$}{\text{hr}} = \25
Benefits = 1.7
Labor Cost = $\frac{1}{4} \cdot \left(8000 \frac{hr}{year}\right) \cdot (8 \text{ Workers}) \cdot \left(\frac{\$25}{hr \cdot Worker}\right) \cdot 1.7$
Labor Cost = $\frac{\$680,000}{yr}$

g. Annual Operating Cost (Total)

$$\begin{array}{l} \textit{Operating Cost} = \textit{Total Product Cost} + \textit{Utility Costs} + \textit{Labor} + \textit{Raw Materials} \\ & \text{Where} \\ \textit{Utility Cost} \equiv \Sigma[\textit{Heating} + \textit{Cooling} + \textit{Electric}]_{\textit{costs}} \\ \textit{Utility Cost} \equiv \$637,280 (see utility summary) \\ \textit{Raw Materials} \equiv \textit{Xylene Purchased}, \textit{Waste Disposed} = \left[\dot{m}_{l} \cdot \left[\frac{\$}{kg}\right]_{l}\right] - 1.5 * \dot{m}_{\textit{waste}} \\ & \text{Where} \\ \dot{m}_{i} \equiv \textit{Mass Flow Rate of Xylene} \\ & \left[\frac{\$}{kg}\right]_{l} = \textit{Price Per Kilogram of Xylene} \\ & \text{Operating Cost} = \$1,464,460 + \$637,280 + \$680,000 + \$795,280 \\ & \text{Annual Operating Cost} = \frac{\$3.57Mil}{year} \text{ with a } 1^{st} \text{ year cost of } \$3.93 \textit{Mil} \\ \end{array}$$

h. SOYD Depreciation Value

$$SOYD \ Depreciation \ (year \ 20) = \frac{0.85 \cdot TCI}{SOYD}$$

$$Where$$

$$SOYD = 210$$

$$Year_{20} \ Depreciation = \left(\frac{0.85}{210}\right) * \$2,515,000 = \$10,182$$

$$Year_{12} \ Depreciation = Year_{20} \ Depreciation * [11 \ Useful \ Years \ Remaining]$$

$$Year_{10} \ Depreciation = \$122,182$$

i. After Tax Cash Flow

 $ATCF = 0.6 \cdot [BTCF - Year_n Deprectation]$ Where

$$BTCF \equiv Revenue - Total Product Cost$$
$$ACTF_{yr12} = 0.6 * [\$6,102,760 - \$91,640] = \$3,698,300$$

j. ROR

The rate of return was calculated in excel using the built-in IRR function with our after tax cash flow as input.

ii. Equipment Sample Calculations

a. Liquid Ring Vacuum Pump

Installed Cost =
$$$28,000 \left(\frac{HP}{10}\right)^{0.5} * 2.62$$

2.62 = Factor to adjust cost from 1981 to 2015
Installed Cost = $$88,600$

b. Mixer:

$$Volume_{70\%} = Vol. Flow in * Holding Time$$
$$Volume_{70\%} = 3.94 \frac{L}{min} * 5 \min * \left(\frac{1m^3}{1000L}\right) = 0.0256m^3$$
$$\frac{Height}{Diameter} = 4 (assumed)$$
$$\therefore H = 0.36m \qquad D = 0.09m$$

c. Column Height

$$\begin{aligned} Height_{Column} &= n_{theoretical} * HETP_{packing} * 1.15 \\ H_{ACN \ Column} &= 23 * 0.08m * 1.15 = 2.39m \end{aligned}$$

d. Flash Drum

$$Flv = \frac{W_l}{W_v} * \left(\frac{\rho_v}{\rho_l}\right)^{.5}$$

$$K_{drum} = e^{A + Bln(Flv) + C(\ln(flv))^2 + D * (\ln(Flv))^3 + E * (\ln(Flv))^4}$$

$$u_{perm} = K_{drum} * \left(\frac{(\rho_l - \rho_v)}{\rho_v}\right)^{.5}$$

$$V = \frac{u_{perm}A_c\rho_v}{MW_{vap}}$$

$$\label{eq:relation} \begin{split} \rho &= \mbox{density} \\ W &= \mbox{mass flow rate} \\ Flv &= \mbox{empirical ratio} \end{split}$$

| Constant | Value | |
|----------|--------------|--|
| А | -1.877478097 | |
| В | 8145804597 | |
| С | 1870744085 | |
| D | 0145228667 | |
| E | 0010148518 | |

 $\begin{array}{l} \text{A-E} = \text{constants} \\ \text{K}_{\text{drum}} = \text{case specific constant} \\ \text{U}_{\text{perm}} = \text{Max velocity at max diameter of flash drum. (Ft/s)} \\ \text{V} = \text{Molar flow rate} \\ \text{A}_{\text{c}} = \text{Cross sectional error} \\ \text{MW}_{\text{vap}} = \text{Molecular weight of the vapor} \end{array}$

e. Storage Tank Volume

$$Volume_{tank} = 2 * V_{50\%}$$
Where:

$$V_{50\%} = \dot{V}_{in} * Fill Time$$
For the ACN Product Tank

$$V_{tank} = 2 \cdot \left(\frac{4.7m^3}{day}\right) \cdot (2 Days) = 18.8m^3$$

Appendix I: References

References

- 1. Wankat, Phillip C. Separation Process Engineering. Upper Saddle River, NJ: Prentice Hall, 2012.
- 2. Blackwell, W. W. Chemical Process Design on a Programmable Calculator. New York: McGraw-Hill, 1984.
- 3. Peters and Timmerhaus (1981)
- Sultzer. Structured Packings. https://www.sulzer.com/en/-/media/Documents/ProductsAndServices/Separation_Technology/Structured_Packings/ Brochures/Structured_Packings.pdf
- 5. Failure Modes and Effects Analysis (FMEA). http://asq.org/learn-about-quality/processanalysis-tools/overview/fmea.html
- 6. Reliasoft. Sample Automotive Process FMEA (PFMEA) generated with Xfmea. http://www.reliasoft.com/pubs/xfmea_pfmea.pd
- 7. http://www.cbme.ust.hk/safetycourse/download/09.1HAZOPStudyTrainingCourse.pdf